


Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Columbus Elementary

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011887-01	Girl Bathroom Sink 2 2nd FL	Lead	99.3	ug/L		15	9/25/2016 8:58	10/13/2016 17:13	EPA 200.8	Drinking Water
S011887-02	Boys Bathroom 1 Sink 2nd FL	Lead	1.20	ug/L		15	9/25/2016 9:01	10/13/2016 17:15	EPA 200.8	Drinking Water
S011887-03	Boys Bathroom 2 Sink 2nd FL	Lead	39.4	ug/L		15	9/25/2016 9:02	10/13/2016 17:17	EPA 200.8	Drinking Water
S011887-04	Water Fountain 1 2nd FL	Lead	1.81	ug/L		15	9/25/2016 9:00	10/13/2016 17:19	EPA 200.8	Drinking Water
S011887-05	Girl Bathroom Sink 1 2nd FL	Lead	<0.50	ug/L		15	9/25/2016 8:58	10/13/2016 17:21	EPA 200.8	Drinking Water
S011887-06	Kitchen Sink 2 Basement	Lead	75.2	ug/L		15	9/25/2016 8:44	10/13/2016 12:22	EPA 200.8	Drinking Water
S011887-07	Girls Bathroom Sink 2 Basement	Lead	4.10	ug/L		15	9/25/2016 8:45	10/13/2016 17:23	EPA 200.8	Drinking Water
S011887-08	Slop Sink 1 Basement	Lead	2.02	ug/L		15	9/25/2016 8:42	10/13/2016 17:26	EPA 200.8	Drinking Water
S011887-09	Girl Bathroom 2 Basement	Lead	11.5	ug/L		15	9/25/2016 8:46	10/13/2016 17:28	EPA 200.8	Drinking Water
S011887-10	Earth Rm. Basement	Lead	261	ug/L		15	9/25/2016 8:40	10/13/2016 12:24	EPA 200.8	Drinking Water
S011887-11	Water Fountain 1 Basement	Lead	1.85	ug/L		15	9/25/2016 8:41	10/13/2016 17:30	EPA 200.8	Drinking Water
S011887-12	Kitchen Sink 1 Basement	Lead	3.72	ug/L		15	9/25/2016 8:43	10/13/2016 17:32	EPA 200.8	Drinking Water
S011887-13	Staff Room 1 Basement	Lead	10.1	ug/L		15	9/25/2016 8:42	10/14/2016 10:27	EPA 200.8	Drinking Water
S011887-14	Boys Bathroom Sink 1 1st FL	Lead	1.18	ug/L		15	9/25/2016 8:50	10/14/2016 10:29	EPA 200.8	Drinking Water
S011887-15	Cafe Sink Basement	Lead	6.55	ug/L		15	9/25/2016 8:44	10/14/2016 10:31	EPA 200.8	Drinking Water
S011887-16	Boys Bathroom Sink Basement	Lead	7.10	ug/L		15	9/25/2016 8:47	10/14/2016 10:34	EPA 200.8	Drinking Water
S011887-17	Water Fountain 2 Basement	Lead	0.54	ug/L		15	9/25/2016 8:47	10/14/2016 10:36	EPA 200.8	Drinking Water
S011887-18	Slop Sink Boys Bathroom 1st FL	Lead	0.71	ug/L		15	9/25/2016 8:51	10/14/2016 10:38	EPA 200.8	Drinking Water
S011887-19	Boys Bathroom Sink 2 1st FL	Lead	7.33	ug/L		15	9/25/2016 8:50	10/14/2016 10:40	EPA 200.8	Drinking Water
S011887-20	Rm 6 Sink 1st FL	Lead	7.60	ug/L		15	9/25/2016 8:52	10/14/2016 10:42	EPA 200.8	Drinking Water
S011887-21	Water Fountain 2 1st FL	Lead	<0.50	ug/L		15	9/25/2016 8:52	10/14/2016 10:44	EPA 200.8	Drinking Water
S011887-22	Girl Bathroom Sink 2 1st FL	Lead	1.78	ug/L		15	9/25/2016 8:57	10/14/2016 10:46	EPA 200.8	Drinking Water
S011887-23	Girl Bathroom Sink 1 1st FL	Lead	0.85	ug/L		15	9/25/2016 8:57	10/14/2016 10:57	EPA 200.8	Drinking Water
S011887-24	Nurse Bathroom 1st FL	Lead	0.85	ug/L		15	9/25/2016 8:56	10/14/2016 10:59	EPA 200.8	Drinking Water
S011887-25	Boys Slop Sink Bathroom 2nd	Lead	1.07	ug/L		15	9/25/2016 9:03	10/14/2016 11:01	EPA 200.8	Drinking Water

Lead analysis performed by ELAP #12406


Dorothy DiNobile

Reviewed by
Dorothy DiNobile, Laboratory Director

Key: <=Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAP) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.

Poughkeepsie City School District
 Jimmy McRay
 11 Collage Avenue
 Poughkeepsie, NY 12603




SMITH
 ENVIRONMENTAL
 LABORATORY

4 Scenic Drive
 Hyde Park, NY 12538
 845-229-6536
 NY ELAP ID: 10924

Poughkeepsie City School District - Poughkeepsie Middle School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012603-01	Main Office Water F	Lead	<0.50	ug/L		15	10/16/2016 12:20	11/15/2016 17:09	EPA 200.8	Drinking Water
S012603-02	Room 122 Sink	Lead	10.9	ug/L		15	10/16/2016 11:24	11/15/2016 17:11	EPA 200.8	Drinking Water
S012603-03	Kitchen Hand Sink	Lead	5.66	ug/L		15	10/16/2016 11:50	11/15/2016 17:13	EPA 200.8	Drinking Water
S012603-04	Kitchen Pot Sink-1	Lead	0.99	ug/L		15	10/16/2016 11:50	11/15/2016 17:15	EPA 200.8	Drinking Water
S012603-05	Kitchen Pot Sink-3	Lead	0.99	ug/L		15	10/16/2016 11:50	11/15/2016 17:17	EPA 200.8	Drinking Water
S012603-06	Library	Lead	6.62	ug/L		15	10/16/2016 14:25	11/15/2016 17:20	EPA 200.8	Drinking Water
S012603-07	Girls Bathroom Sink 1, 2nd Floor	Lead	0.84	ug/L		15	10/16/2016 14:05	11/15/2016 17:22	EPA 200.8	Drinking Water
S012603-08	Pool Boys	Lead	2.84	ug/L		15	10/16/2016 12:13	11/15/2016 17:24	EPA 200.8	Drinking Water
S012603-09	Lob Girls Bathroom Sink-1, Main Floor	Lead	0.62	ug/L		15	10/16/2016 12:17	11/15/2016 17:26	EPA 200.8	Drinking Water
S012603-10	Room 111 Sink	Lead	3.59	ug/L		15	10/16/2016 0:00	11/15/2016 17:28	EPA 200.8	Drinking Water
S012603-11	Boys Bathroom Lobby Sink-2	Lead	0.98	ug/L		15	10/16/2016 12:15	11/15/2016 17:38	EPA 200.8	Drinking Water
S012603-12	Girls Bathroom Staff, 2nd Floor	Lead	1.63	ug/L		15	10/16/2016 14:00	11/15/2016 17:41	EPA 200.8	Drinking Water
S012603-13	Room 110 Water	Lead	162	ug/L		15	10/16/2016 13:10	11/15/2016 17:43	EPA 200.8	Drinking Water
S012603-14	Room 119 Sink	Lead	6.63	ug/L		15	10/16/2016 12:56	11/15/2016 17:45	EPA 200.8	Drinking Water
S012603-15	Water F Room 120	Lead	12.4	ug/L		15	10/16/2016 12:56	11/15/2016 17:47	EPA 200.8	Drinking Water
S012603-16	Boy Bathroom Sink-3, 1st Floor	Lead	2.06	ug/L		15	10/16/2016 13:25	11/15/2016 17:49	EPA 200.8	Drinking Water
S012603-17	Room 107 Sink	Lead	4.25	ug/L		15	10/16/2016 13:24	11/15/2016 17:51	EPA 200.8	Drinking Water
S012603-18	Room 105 Sink	Lead	2.85	ug/L		15	10/16/2016 13:16	11/15/2016 17:53	EPA 200.8	Drinking Water
S012603-19	Gym Water F	Lead	<0.50	ug/L		15	10/16/2016 12:15	11/15/2016 17:57	EPA 200.8	Drinking Water

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603




SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Poughkeepsie Middle School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012603-20	Nurse Office	Lead	3.55	ug/L		15	10/16/2016 12:20	11/29/2016 14:38	EPA 200.8	Drinking Water
S012603-21	Boy Bathroom Sink-2, 1st Floor	Lead	1.18	ug/L		15	10/16/2016 13:25	11/15/2016 17:59	EPA 200.8	Drinking Water
S012603-22	Room 102 Water F	Lead	1.37	ug/L		15	10/16/2016 13:18	11/15/2016 18:10	EPA 200.8	Drinking Water
S012603-23	Room 103 Sink	Lead	5.87	ug/L		15	10/16/2016 13:26	11/15/2016 18:12	EPA 200.8	Drinking Water
S012603-24	Room 002	Lead	3.85	ug/L		15	10/16/2016 11:40	11/15/2016 18:14	EPA 200.8	Drinking Water
S012603-25	Room 115 Sink	Lead	32.0	ug/L		15	10/16/2016 12:30	11/15/2016 18:16	EPA 200.8	Drinking Water
S012603-26	Girls Bathroom Sink 3, 2nd Floor	Lead	5.92	ug/L		15	10/16/2016 14:05	11/15/2016 18:18	EPA 200.8	Drinking Water
S012603-27	Room 101 Water Fan	Lead	15.5	ug/L		15	10/16/2016 13:15	11/15/2016 18:20	EPA 200.8	Drinking Water
S012603-28	Water F, 2nd Floor	Lead	4.53	ug/L		15	10/16/2016 14:15	11/15/2016 18:23	EPA 200.8	Drinking Water
S012603-29	Room 113 Water F	Lead	2.31	ug/L		15	10/16/2016 11:24	11/15/2016 18:25	EPA 200.8	Drinking Water
S012603-30	Pool Girls	Lead	0.66	ug/L		15	10/16/2016 12:13	11/15/2016 18:27	EPA 200.8	Drinking Water
S012603-31	Room 116 Sink	Lead	4.15	ug/L		15	10/16/2016 12:25	11/15/2016 18:29	EPA 200.8	Drinking Water
S012603-32	Main Office Sink	Lead	1.24	ug/L		15	10/16/2016 12:20	11/15/2016 18:39	EPA 200.8	Drinking Water
S012603-33	Room 102 Sink	Lead	5.83	ug/L		15	10/16/2016 13:18	11/15/2016 18:41	EPA 200.8	Drinking Water
S012603-34	Girls Bathroom Sink-1	Lead	1.02	ug/L		15	10/16/2016 13:05	11/15/2016 18:44	EPA 200.8	Drinking Water
S012603-35	Girls Bathroom Sink-3, Main Lobby	Lead	1.11	ug/L		15	10/16/2016 12:17	11/15/2016 18:46	EPA 200.8	Drinking Water
S012603-36	Girls Bathroom Sink-2, 1st Floor East	Lead	3.28	ug/L		15	10/16/2016 13:05	11/15/2016 18:50	EPA 200.8	Drinking Water
S012603-37	Boys Bathroom Sink-4, 2nd Floor	Lead	0.57	ug/L		15	10/16/2016 14:17	11/15/2016 18:52	EPA 200.8	Drinking Water
S012603-38	Boys Bathroom Sink-2	Lead	2.57	ug/L		15	10/16/2016 14:09	11/15/2016 18:54	EPA 200.8	Drinking Water

Poughkeepsie City School District
 Jimmy McRay
 11 Collage Avenue
 Poughkeepsie, NY 12603




SMITH
 ENVIRONMENTAL
 LABORATORY

4 Scenic Drive
 Hyde Park, NY 12538
 845-229-6536
 NY ELAP ID: 10924

Poughkeepsie City School District - Poughkeepsie Middle School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012603-39	Boys Bathroom Sink-1	Lead	0.87	ug/L		15	10/16/2016 14:09	11/15/2016 18:56	EPA 200.8	Drinking Water
S012603-40	Water F, 3rd Floor East	Lead	1.44	ug/L		15	10/16/2016 14:50	11/15/2016 18:58	EPA 200.8	Drinking Water
S012603-41	Boys Bathroom Sink-3, 2nd Floor North	Lead	1.34	ug/L		15	10/16/2016 14:17	11/15/2016 19:00	EPA 200.8	Drinking Water
S012603-42	Bathroom Sink-2, 3rd Floor	Lead	1.56	ug/L		15	10/16/2016 14:25	11/16/2016 9:20	EPA 200.8	Drinking Water
S012603-43	Girls Bathroom Sink-4, 3rd Floor East	Lead	2.43	ug/L		15	10/16/2016 0:00	11/16/2016 9:22	EPA 200.8	Drinking Water
S012603-44	Girls Bathroom Sink-2, 3rd Floor South	Lead	1.51	ug/L		15	10/16/2016 14:20	11/16/2016 9:24	EPA 200.8	Drinking Water
S012603-45	Boys Bathroom Sink-1, 2nd Floor North	Lead	1.53	ug/L		15	10/16/2016 14:13	11/16/2016 9:27	EPA 200.8	Drinking Water
S012603-46	Room 212, 2nd Floor	Lead	0.66	ug/L		15	10/16/2016 14:03	11/16/2016 9:29	EPA 200.8	Drinking Water
S012603-47	Girls Bathroom Sink-4, 2nd Floor North	Lead	2.89	ug/L		15	10/16/2016 14:17	11/16/2016 9:31	EPA 200.8	Drinking Water
S012603-48	Room 217B	Lead	2.35	ug/L		15	10/16/2016 14:08	11/16/2016 9:33	EPA 200.8	Drinking Water
S012603-49	Girls Bathroom Sink 3, 3rd Floor	Lead	1.05	ug/L		15	10/16/2016 14:30	11/16/2016 9:35	EPA 200.8	Drinking Water
S012603-50	Room 212 Sink-1, 2nd Floor	Lead	3.94	ug/L		15	10/16/2016 14:12	11/16/2016 9:37	EPA 200.8	Drinking Water
S012603-51	Girls Bathroom Sink-3, 2nd Floor North	Lead	3.35	ug/L		15	10/16/2016 14:17	11/16/2016 9:39	EPA 200.8	Drinking Water
S012603-52	Boys Bathroom Sink-3, 3rd Floor North	Lead	3.51	ug/L		15	10/16/2016 14:28	11/16/2016 14:58	EPA 200.8	Drinking Water
S012603-53	Boys Bathroom Sink-1, 3rd Floor North	Lead	9.61	ug/L		15	10/16/2016 14:28	11/16/2016 15:00	EPA 200.8	Drinking Water
S012603-54	Girls Bathroom Sink-1, 3rd Floor South	Lead	1.85	ug/L		15	10/16/2016 14:50	11/16/2016 15:02	EPA 200.8	Drinking Water
S012603-55	Room 307 Sink-2	Lead	4.54	ug/L		15	10/16/2016 0:00	11/16/2016 15:05	EPA 200.8	Drinking Water
S012603-56	Girls Bathroom Sink-2, 2nd Floor North	Lead	2.36	ug/L		15	10/16/2016 0:00	11/16/2016 15:07	EPA 200.8	Drinking Water
S012603-57	Girls Bathroom Sink-2, 3rd Floor East	Lead	1.20	ug/L		15	10/16/2016 0:00	11/16/2016 15:09	EPA 200.8	Drinking Water

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Poughkeepsie Middle School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012603-58	Girls Bathroom Sink-1, 3rd Floor East	Lead	1.71	ug/L		15	10/16/2016 0:00	11/16/2016 15:11	EPA 200.8	Drinking Water
S012603-59	Room 307, Sink-1	Lead	5.83	ug/L		15	10/16/2016 0:00	11/16/2016 15:13	EPA 200.8	Drinking Water
S012603-60	Girls Bathroom Sink-2, 2nd Floor	Lead	2.29	ug/L		15	10/16/2016 14:45	11/16/2016 15:15	EPA 200.8	Drinking Water
S012603-61	Boys Bathroom Sink-2, 3rd Floor East	Lead	3.17	ug/L		15	10/16/2016 0:00	11/16/2016 15:18	EPA 200.8	Drinking Water
S012603-62	Room 307 Sink-4	Lead	2.08	ug/L		15	10/16/2016 0:00	11/16/2016 16:40	EPA 200.8	Drinking Water
S012603-63	Boys Bathroom Sink-3, 3rd Floor East	Lead	1.96	ug/L		15	10/16/2016 14:45	11/16/2016 16:42	EPA 200.8	Drinking Water
S012603-64	Boys Bathroom Sink-2, 2nd Floor North	Lead	4.98	ug/L		15	10/16/2016 14:28	11/16/2016 16:44	EPA 200.8	Drinking Water
S012603-65	Girls Bathroom Sink-3, 3rd Floor East	Lead	2.50	ug/L		15	10/16/2016 0:00	11/16/2016 16:46	EPA 200.8	Drinking Water
S012603-66	Water F East 2, 3rd Floor	Lead	1.39	ug/L		15	10/16/2016 14:36	11/16/2016 16:48	EPA 200.8	Drinking Water
S012603-67	Boys Bathroom Sink-2, 2nd Floor North	Lead	2.85	ug/L		15	10/16/2016 14:17	11/16/2016 16:51	EPA 200.8	Drinking Water
S012603-68	Boys Bathroom Sink, 2nd Floor East	Lead	5.00	ug/L		15	10/16/2016 14:09	11/16/2016 16:53	EPA 200.8	Drinking Water
S012603-69	Room 215 Sink-2	Lead	2.76	ug/L		15	10/16/2016 14:10	11/16/2016 16:55	EPA 200.8	Drinking Water
S012603-70	Boys Bathroom Sink-4, 3rd Floor East	Lead	2.78	ug/L		15	10/16/2016 14:45	11/16/2016 16:57	EPA 200.8	Drinking Water
S012603-71	Boys Bathroom Sink-3	Lead	2.27	ug/L		15	10/16/2016 14:09	11/16/2016 16:59	EPA 200.8	Drinking Water
S012603-72	Boys Bathroom Sink-1, 3rd Floor East	Lead	6.80	ug/L		15	10/16/2016 14:45	11/16/2016 17:10	EPA 200.8	Drinking Water
S012603-73	Room 307 Sink-3	Lead	2.58	ug/L		15	10/16/2016 0:00	11/16/2016 17:12	EPA 200.8	Drinking Water
S012603-74	Boys Bathroom Sink-4, 1st Floor	Lead	1.56	ug/L		15	10/16/2016 0:00	11/16/2016 17:14	EPA 200.8	Drinking Water
S012603-75	Water F, 2nd Floor	Lead	<0.50	ug/L		15	10/16/2016 14:04	11/16/2016 17:16	EPA 200.8	Drinking Water
S012603-76	Boys Sink-2, 1st Floor East	Lead	1.58	ug/L		15	10/16/2016 13:01	11/16/2016 17:19	EPA 200.8	Drinking Water

Poughkeepsie City School District
 Jimmy McRay
 11 Collage Avenue
 Poughkeepsie, NY 12603




SMITH
 ENVIRONMENTAL
 LABORATORY

4 Scenic Drive
 Hyde Park, NY 12538
 845-229-6536
 NY ELAP ID: 10924

Poughkeepsie City School District - Poughkeepsie Middle School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012603-77	Restroom Sink-3, Basement North	Lead	1.51	ug/L		15	10/16/2016 11:21	11/16/2016 17:21	EPA 200.8	Drinking Water
S012603-78	Restroom Sink-1, Basement North	Lead	24.9	ug/L		15	10/16/2016 11:22	11/16/2016 17:23	EPA 200.8	Drinking Water
S012603-79	Kitchen Storm Pot	Lead	1.54	ug/L		15	10/16/2016 0:00	11/16/2016 17:25	EPA 200.8	Drinking Water
S012603-80	Room 113 Sink	Lead	3.18	ug/L		15	10/16/2016 0:00	11/16/2016 17:29	EPA 200.8	Drinking Water
S012603-81	Room 118 Sink	Lead	6.13	ug/L		15	10/16/2016 12:26	11/16/2016 17:31	EPA 200.8	Drinking Water
S012603-82	Boys Bathroom Sink-3, 1st Floor East	Lead	3.87	ug/L		15	10/16/2016 13:01	11/16/2016 17:42	EPA 200.8	Drinking Water
S012603-83	Room 103 Water F	Lead	2.71	ug/L		15	10/16/2016 13:25	11/16/2016 17:44	EPA 200.8	Drinking Water
S012603-84	Room 104 Water F	Lead	3.01	ug/L		15	10/16/2016 13:22	11/16/2016 17:47	EPA 200.8	Drinking Water
S012603-85	Boys Locker Room Sink-1	Lead	11.5	ug/L		15	10/16/2016 11:30	11/16/2016 17:49	EPA 200.8	Drinking Water
S012603-86	Basement Room 010	Lead	368	ug/L		15	10/16/2016 11:16	11/29/2016 14:40	EPA 200.8	Drinking Water
S012603-87	Student Service	Lead	151	ug/L		15	10/16/2016 11:36	11/16/2016 17:51	EPA 200.8	Drinking Water
S012603-88	Lobby Water F	Lead	<0.50	ug/L		15	10/16/2016 12:16	11/16/2016 17:53	EPA 200.8	Drinking Water
S012603-89	Boys Bathroom Sink 4, 1st Floor East	Lead	1.38	ug/L		15	10/16/2016 13:01	11/16/2016 17:55	EPA 200.8	Drinking Water
S012603-90	Water F, 3rd Floor South	Lead	<0.50	ug/L		15	10/16/2016 14:29	11/16/2016 17:57	EPA 200.8	Drinking Water
S012603-91	Girls C & R Sink, Basement	Lead	3.05	ug/L		15	10/16/2016 11:45	11/16/2016 18:00	EPA 200.8	Drinking Water
S012603-92	Girls Bathroom Sink-1, 1st Floor North	Lead	1.83	ug/L		15	10/16/2016 0:00	11/16/2016 18:02	EPA 200.8	Drinking Water
S012603-93	Bathroom Sink-1, 3rd Floor	Lead	12.8	ug/L		15	10/16/2016 14:15	11/16/2016 18:13	EPA 200.8	Drinking Water
S012603-94	Water F, Basement	Lead	<0.50	ug/L		15	10/16/2016 11:19	11/16/2016 18:15	EPA 200.8	Drinking Water
S012603-95	Water F, 1st Floor	Lead	<0.50	ug/L		15	10/16/2016 13:20	11/16/2016 18:17	EPA 200.8	Drinking Water

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Poughkeepsie Middle School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012603-96	Girls Bathroom Sink-2, Basement	Lead	0.85	ug/L		15	10/16/2016 11:46	11/16/2016 18:19	EPA 200.8	Drinking Water

Lead analysis performed by ELAP #12406

Reviewed by

Dorothy DiNobile, Laboratory Director

Key: <=Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.

Poughkeepsie City School District
 Jimmy McRay
 11 Collage Avenue
 Poughkeepsie, NY 12603



SMITH
 ENVIRONMENTAL
 LABORATORY

4 Scenic Drive
 Hyde Park, NY 12538
 845-229-6536
 NY ELAP ID: 10924

Poughkeepsie City School District - Clinton Elementary

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011884-01	3 Sink Boys 2nd Floor	Lead	<0.50	ug/L		15	9/18/2016 9:20	10/17/2016 10:28	EPA 200.8	Drinking Water
S011884-02	1 Sink Boys 2nd Floor	Lead	<0.50	ug/L		15	9/18/2016 9:20	10/17/2016 10:30	EPA 200.8	Drinking Water
S011884-03	Water Fountain West 2nd Floor	Lead	<0.50	ug/L		15	9/18/2016 9:20	10/17/2016 10:32	EPA 200.8	Drinking Water
S011884-04	Sink 2 1st FL Girls	Lead	<0.50	ug/L		15	9/18/2016 9:00	10/17/2016 10:35	EPA 200.8	Drinking Water
S011884-05	Sink 1 1st FL Girls	Lead	0.88	ug/L		15	9/18/2016 9:12	10/17/2016 10:37	EPA 200.8	Drinking Water
S011884-06	Sink 3 1st FL Girls	Lead	<0.50	ug/L		15	9/18/2016 9:12	10/17/2016 10:39	EPA 200.8	Drinking Water
S011884-07	Nurse Restroom 1st FL	Lead	0.88	ug/L		15	9/18/2016 9:15	10/17/2016 10:41	EPA 200.8	Drinking Water
S011884-08	1 Sink Rm 30 Basement	Lead	0.70	ug/L		15	9/18/2016 9:09	10/17/2016 10:43	EPA 200.8	Drinking Water
S011884-09	Principal Office 1st FL	Lead	2.09	ug/L		15	9/18/2016 9:13	10/17/2016 10:45	EPA 200.8	Drinking Water
S011884-10	Water Fountain West 1st FL	Lead	<0.50	ug/L		15	9/18/2016 9:15	10/17/2016 10:47	EPA 200.8	Drinking Water
S011884-11	1 Sink 1st FL Boy	Lead	<0.50	ug/L		15	9/18/2016 9:15	10/17/2016 10:58	EPA 200.8	Drinking Water
S011884-12	Kitchen 1 Sink	Lead	0.55	ug/L		15	9/18/2016 9:15	10/17/2016 11:00	EPA 200.8	Drinking Water
S011884-13	Kitchen 2 Sink	Lead	<0.50	ug/L		15	9/18/2016 9:15	10/17/2016 11:02	EPA 200.8	Drinking Water
S011884-14	Kitchen 3 Sink	Lead	0.89	ug/L		15	9/18/2016 9:15	10/17/2016 11:04	EPA 200.8	Drinking Water
S011884-15	Water Fountain East	Lead	<0.50	ug/L		15	9/18/2016 9:16	10/17/2016 11:06	EPA 200.8	Drinking Water
S011884-16	Sink #2 1st FL Boy Room	Lead	<0.50	ug/L		15	9/18/2016 9:15	10/17/2016 11:08	EPA 200.8	Drinking Water
S011884-17	Water Fountain East	Lead	<0.50	ug/L		15	9/18/2016 9:17	10/17/2016 11:10	EPA 200.8	Drinking Water
S011884-18	Sink #1 Girls Room	Lead	0.52	ug/L		15	9/18/2016 9:17	10/17/2016 11:12	EPA 200.8	Drinking Water
S011884-19	Sink #3 Girls Room	Lead	0.53	ug/L		15	9/18/2016 9:17	10/17/2016 11:16	EPA 200.8	Drinking Water
S011884-20	Sink #2 Boys Room	Lead	<0.50	ug/L		15	9/18/2016 9:20	10/17/2016 11:19	EPA 200.8	Drinking Water
S011884-21	Girls Bathroom 1 Sink	Lead	<0.50	ug/L		15	9/18/2016 9:10	10/16/2016 11:22	EPA 200.8	Drinking Water
S011884-22	Girls Bathroom 2 Sink	Lead	0.90	ug/L		15	9/18/2016 9:10	10/16/2016 11:24	EPA 200.8	Drinking Water
S011884-23	Room 30 2 Sink Basement	Lead	4.29	ug/L		15	9/18/2016 9:08	10/16/2016 11:26	EPA 200.8	Drinking Water
S011884-24	East Water Fountain	Lead	<0.50	ug/L		15	9/18/2016 9:08	10/16/2016 11:28	EPA 200.8	Drinking Water
S011884-25	Art Room Basement	Lead	2.63	ug/L		15	9/18/2016 9:08	10/16/2016 11:30	EPA 200.8	Drinking Water
S011884-26	1 Sink Boys Basement	Lead	<0.50	ug/L		15	9/18/2016 9:07	10/16/2016 11:32	EPA 200.8	Drinking Water
S011884-27	2 Sink Boys Basement	Lead	<0.50	ug/L		15	9/18/2016 9:06	10/16/2016 11:34	EPA 200.8	Drinking Water
S011884-28	Office Restroom 1st FL	Lead	2.09	ug/L		15	9/18/2016 9:19	10/16/2016 11:36	EPA 200.8	Drinking Water
S011884-29	Staff Restroom 1st FL	Lead	<0.50	ug/L		15	9/18/2016 9:11	10/16/2016 11:39	EPA 200.8	Drinking Water
S011884-30	3 Sink 1st FL Boys 1st FL	Lead	0.96	ug/L		15	9/18/2016 9:15	10/16/2016 11:41	EPA 200.8	Drinking Water

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Clinton Elementary

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix

Lead analysis performed by ELAP #12406


Key: <=Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Reviewed by

Dorothy DiNobile, Laboratory Director

Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Kreiger Elementary

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011886-01	Library Sink Water 1st FL	Lead	14.20	ug/L		15	9/18/2016 10:50	10/29/2016 10:12	EPA 200.8	Drinking Water
S011886-02	Water Fountain South Side 1st	Lead	<0.50	ug/L		15	9/18/2016 11:50	10/29/2016 10:14	EPA 200.8	Drinking Water
S011886-03	Music Rm. Water Ft 1st FL	Lead	1.19	ug/L		15	9/18/2016 10:55	10/29/2016 10:16	EPA 200.8	Drinking Water
S011886-04	Boys Old Wing Sink 4	Lead	1.31	ug/L		15	9/18/2016 10:55	10/29/2016 10:18	EPA 200.8	Drinking Water
S011886-05	Boys Old Wing Sink 2	Lead	3.54	ug/L		15	9/18/2016 10:54	10/29/2016 10:21	EPA 200.8	Drinking Water
S011886-06	Girls Bathroom Sink 3 1st FL	Lead	1.70	ug/L		15	9/18/2016 11:55	10/29/2016 10:23	EPA 200.8	Drinking Water
S011886-07	Boys Old Wing Sink 3	Lead	12.80	ug/L		15	9/18/2016 10:55	11/2/2016 9:53	EPA 200.8	Drinking Water
S011886-08	Girls Bathroom Sink 1 1st FL	Lead	0.78	ug/L		15	9/18/2016 11:58	10/29/2016 10:25	EPA 200.8	Drinking Water
S011886-09	RM 106 Sink 1st FL	Lead	1.07	ug/L		15	9/18/2016 11:55	10/29/2016 10:27	EPA 200.8	Drinking Water
S011886-10	Water F. S. 2 1st FL	Lead	<0.50	ug/L		15	9/18/2016 11:55	10/29/2016 10:29	EPA 200.8	Drinking Water
S011886-11	1st FL Principal Office	Lead	1.31	ug/L		15	9/18/2016 11:47	10/29/2016 10:31	EPA 200.8	Drinking Water
S011886-12	1st FL Boy Bathroom Sink 1	Lead	<0.50	ug/L		15	9/18/2016 11:45	10/29/2016 10:42	EPA 200.8	Drinking Water
S011886-14	1st FL Boy Bathroom Sink 3	Lead	<0.50	ug/L		15	9/18/2016 11:45	10/29/2016 10:44	EPA 200.8	Drinking Water
S011886-15	1st FL Girls Bathroom Sink 1	Lead	1.24	ug/L		15	9/18/2016 11:47	10/29/2016 10:46	EPA 200.8	Drinking Water
S011886-16	1st FL Girls Bathroom Sink 2	Lead	<0.50	ug/L		15	9/18/2016 11:46	10/29/2016 10:48	EPA 200.8	Drinking Water
S011886-17	1st FL Girls Bathroom Sink 3	Lead	<0.50	ug/L		15	9/18/2016 11:47	10/29/2016 10:50	EPA 200.8	Drinking Water
S011886-18	1st FL Girls Bathroom Sink 4	Lead	1.24	ug/L		15	9/18/2016 11:40	10/29/2016 10:52	EPA 200.8	Drinking Water
S011886-19	1st FL Nurse Sink	Lead	0.73	ug/L		15	9/18/2016 11:40	10/29/2016 10:54	EPA 200.8	Drinking Water
S011886-20	1st FL Rm. 115 Sink	Lead	<0.50	ug/L		15	9/18/2016 11:49	10/29/2016 10:56	EPA 200.8	Drinking Water
S011886-21	Room 220 Sink 2nd FL	Lead	0.78	ug/L		15	9/18/2016 12:12	10/29/2016 11:00	EPA 200.8	Drinking Water
S011886-22	Room 220 Water F. 2nd FL	Lead	<0.50	ug/L		15	9/18/2016 12:12	10/29/2016 11:03	EPA 200.8	Drinking Water
S011886-23	Room 218 2nd FL Sink	Lead	2.69	ug/L		15	9/18/2016 12:12	10/29/2016 11:13	EPA 200.8	Drinking Water
S011886-24	2nd FL Rm 223 Water F	Lead	<0.50	ug/L		15	9/18/2016 12:15	10/29/2016 11:15	EPA 200.8	Drinking Water
S011886-25	2nd FL Rm 223 Sink	Lead	0.60	ug/L		15	9/18/2016 12:15	10/29/2016 11:17	EPA 200.8	Drinking Water
S011886-26	2nd FL Rm 222 Sink	Lead	<0.50	ug/L		15	9/18/2016 12:15	10/29/2016 11:19	EPA 200.8	Drinking Water
S011886-27	2nd FL Rm 222 Water F.	Lead	<0.50	ug/L		15	9/18/2016 12:15	10/29/2016 11:21	EPA 200.8	Drinking Water
S011886-31	2nd FL Rm 215 Water F.	Lead	<0.50	ug/L		15	9/18/2016 12:08	10/29/2016 11:30	EPA 200.8	Drinking Water
S011886-38	2nd FL Girls Bathroom	Lead	0.80	ug/L		15	9/18/2016 12:08	10/29/2016 12:44	EPA 200.8	Drinking Water
S011886-39	2nd FL Girls Bathroom	Lead	0.72	ug/L		15	9/18/2016 12:08	10/29/2016 12:46	EPA 200.8	Drinking Water
S011886-43	2nd FL Girls Bathroom Sink 3	Lead	1.66	ug/L		15	9/18/2016 12:05	10/29/2016 13:03	EPA 200.8	Drinking Water

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Kreiger Elementary

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011886-50	2nd FL Water F. Next to Rm. 205	Lead	<0.50	ug/L		15	9/18/2016 12:05	10/29/2016 13:17	EPA 200.8	Drinking Water
S011886-51	1st FL South Side Water F.	Lead	<0.50	ug/L		15	9/18/2016 12:03	10/29/2016 13:22	EPA 200.8	Drinking Water
S011886-55	1st FL Restroom Nurse Sink	Lead	<0.50	ug/L		15	9/18/2016 11:47	10/29/2016 13:39	EPA 200.8	Drinking Water
S011886-62	Boys Old Wing Sink 1 1st FL	Lead	1.39	ug/L		15	9/18/2016 10:54	10/29/2016 13:53	EPA 200.8	Drinking Water
S011886-63	Girls Bathroom Sink 2	Lead	1.44	ug/L		15	9/18/2016 11:55	10/30/2016 18:48	EPA 200.8	Drinking Water
S011886-28	2nd FL Rm 221 Sink	Lead	0.98	ug/L		15	9/18/2016 12:10	10/29/2016 11:24	EPA 200.8	Drinking Water
S011886-29	2nd FL Rm 221 Water F.	Lead	<0.50	ug/L		15	9/18/2016 12:10	10/29/2016 11:28	EPA 200.8	Drinking Water
S011886-30	2nd FL Rm 203 Sink	Lead	1.63	ug/L		15	9/18/2016 12:05	10/29/2016 11:28	EPA 200.8	Drinking Water
S011886-34	2nd FL Boy Bathroom Sink 1	Lead	3.75	ug/L		15	9/18/2016 12:10	10/29/2016 12:35	EPA 200.8	Drinking Water
S011886-41	2nd FL Girls Bathroom Sink 1	Lead	1.09	ug/L		15	9/18/2016 12:05	10/29/2016 12:50	EPA 200.8	Drinking Water
S011886-42	2nd FL Girls Bathroom Sink 2	Lead	0.65	ug/L		15	9/18/2016 12:05	10/29/2016 12:52	EPA 200.8	Drinking Water
S011886-46	2nd FL Old Wing Boy BR	Lead	1.24	ug/L		15	9/18/2016 12:06	10/29/2016 13:09	EPA 200.8	Drinking Water
S011886-53	1st FL Room 182 Sink	Lead	0.63	ug/L		15	9/18/2016 12:02	10/29/2016 13:34	EPA 200.8	Drinking Water
S011886-54	1st FL Restroom 111 Sink	Lead	0.70	ug/L		15	9/18/2016 11:47	10/29/2016 13:36	EPA 200.8	Drinking Water
S011886-58	B/M Kitchen Sink 1	Lead	1.10	ug/L		15	9/18/2016 11:40	10/29/2016 13:45	EPA 200.8	Drinking Water
S011886-32	2nd FL Rm 218 Water F.	Lead	<0.50	ug/L		15	9/18/2016 12:12	10/29/2016 11:32	EPA 200.8	Drinking Water
S011886-33	2nd FL Rm 219 Sink	Lead	0.96	ug/L		15	9/18/2016 12:08	10/29/2016 12:33	EPA 200.8	Drinking Water
S011886-37	2nd FL Staff Room Sink	Lead	0.58	ug/L		15	9/18/2016 12:07	10/29/2016 12:41	EPA 200.8	Drinking Water
S011886-44	2nd FL Girls Bathroom Sink 4	Lead	2.04	ug/L		15	9/18/2016 12:05	10/29/2016 13:05	EPA 200.8	Drinking Water
S011886-45	2nd FL Old Wing Boy BR	Lead	1.58	ug/L		15	9/18/2016 12:06	10/29/2016 13:07	EPA 200.8	Drinking Water
S011886-49	2nd FL Water F. Next to Rm. 212	Lead	<0.50	ug/L		15	9/18/2016 12:05	10/29/2016 13:15	EPA 200.8	Drinking Water
S011886-56	B/M Kitchen Sink 2	Lead	0.58	ug/L		15	9/18/2016 11:40	10/29/2016 13:41	EPA 200.8	Drinking Water
S011886-57	B/M Kitchen Sink 3	Lead	1.56	ug/L		15	9/18/2016 11:40	10/29/2016 13:43	EPA 200.8	Drinking Water
S011886-61	Music Rm. Sink 1st FL	Lead	8.10	ug/L		15	9/18/2016 11:50	10/29/2016 13:51	EPA 200.8	Drinking Water
S011886-35	2nd FL Boy Bathroom Sink 2	Lead	0.67	ug/L		15	9/18/2016 12:10	10/29/2016 12:37	EPA 200.8	Drinking Water
S011886-36	2nd FL Boy Bathroom Sink 3	Lead	0.93	ug/L		15	9/18/2016 12:10	10/29/2016 12:39	EPA 200.8	Drinking Water
S011886-40	2nd FL Girls Bathroom	Lead	<0.50	ug/L		16	9/18/2016 12:08	10/29/2016 12:48	EPA 200.8	Drinking Water
S011886-47	2nd FL Old Wing Boy BR	Lead	0.53	ug/L		17	9/18/2016 12:06	10/29/2016 13:11	EPA 200.8	Drinking Water
S011886-48	2nd FL Old Wing Boy BR	Lead	0.54	ug/L		18	9/18/2016 12:06	10/29/2016 13:13	EPA 200.8	Drinking Water
S011886-52	1st FL Room 104 Sink	Lead	5.61	ug/L		19	9/18/2016 12:00	10/29/2016 13:24	EPA 200.8	Drinking Water

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Kreiger Elementary

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011886-59	1st FL Room 115 Water F.	Lead	<0.50	ug/L		20	9/18/2016 11:48	10/29/2016 13:47	EPA 200.8	Drinking Water
S011886-60	1st FL Room 111 Sink	Lead	0.58	ug/L		21	9/18/2016 11:47	10/29/2016 13:49	EPA 200.8	Drinking Water

Lead analysis performed by ELAP #12406

Reviewed by

Dorothy DiNobile, Laboratory Director

Key: <=Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Morse Elementary

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011883-01	Rm. 110 Sink Basement	Lead	0.53	ug/L		15	9/24/2016 11:46	10/13/2016 20:25	EPA 200.8	Drinking Water
S011883-02	Girl Bathroom Sink Basement	Lead	<0.50	ug/L		15	9/24/2016 11:45	10/13/2016 20:27	EPA 200.8	Drinking Water
S011883-03	Rm. 111 Water Fountain	Lead	<0.50	ug/L		15	9/24/2016 11:47	10/13/2016 20:29	EPA 200.8	Drinking Water
S011883-04	Boys Bathroom Sink Basement	Lead	<0.50	ug/L		15	9/24/2016 11:46	10/13/2016 20:31	EPA 200.8	Drinking Water
S011883-05	2 Girl Sink Bathroom Old	Lead	1.68	ug/L		15	9/24/2016 11:56	10/13/2016 20:36	EPA 200.8	Drinking Water
S011883-06	Rm. 112 Water Fountain	Lead	<0.50	ug/L		15	9/24/2016 11:48	10/13/2016 20:38	EPA 200.8	Drinking Water
S011883-07	Slop Sink 1 Basement	Lead	9.99	ug/L		15	9/24/2016 11:30	10/13/2016 12:33	EPA 200.8	Drinking Water
S011883-08	Art Rm. Sink 1 Basement	Lead	297	ug/L		15	9/24/2016 11:41	10/13/2016 12:43	EPA 200.8	Drinking Water
S011883-09	B/M Room 111 Sink	Lead	<0.50	ug/L		15	9/24/2016 11:40	10/13/2016 20:48	EPA 200.8	Drinking Water
S011883-10	B/M Room 110 Water Fountain	Lead	<0.50	ug/L		15	9/24/2016 11:46	10/13/2016 20:50	EPA 200.8	Drinking Water
S011883-11	B/M Water F 2	Lead	1.64	ug/L		15	9/24/2016 11:36	10/13/2016 20:53	EPA 200.8	Drinking Water
S011883-12	1st Floor Girls BR Sink 1	Lead	0.76	ug/L		15	9/24/2016 11:56	10/13/2016 20:55	EPA 200.8	Drinking Water
S011883-13	Room 106 Sink Sink	Lead	1.58	ug/L		15	9/24/2016 11:35	10/13/2016 20:57	EPA 200.8	Drinking Water
S011883-14	Kitchen Slop Sink 1st Floor	Lead	18.8	ug/L		15	9/24/2016 11:54	10/13/2016 20:59	EPA 200.8	Drinking Water
S011883-15	Nurses Sink 1st FL	Lead	3.77	ug/L		15	9/24/2016 12:00	10/13/2016 21:01	EPA 200.8	Drinking Water
S011883-16	Kitchen Sink 3 1st FL	Lead	<0.50	ug/L		15	9/24/2016 11:53	10/13/2016 21:03	EPA 200.8	Drinking Water
S011883-17	Slop Sink 1 1st FL	Lead	17.1	ug/L		15	9/24/2016 11:49	10/13/2016 21:05	EPA 200.8	Drinking Water
S011883-18	Rm. 109 Sink Basement	Lead	11.2	ug/L		15	9/24/2016 11:45	10/13/2016 21:08	EPA 200.8	Drinking Water
S011883-19	1st FL Water Fountain 1 1st	Lead	<0.50	ug/L		15	9/24/2016 11:49	10/13/2016 21:18	EPA 200.8	Drinking Water
S011883-20	Art Room Sink 2 Basement	Lead	6.66	ug/L		15	9/24/2016 11:42	10/13/2016 21:20	EPA 200.8	Drinking Water
S011883-21	Kitchen Sink 2 1st FL	Lead	<0.50	ug/L		15	9/24/2016 11:51	10/13/2016 21:22	EPA 200.8	Drinking Water
S011883-22	Loft Basement Bathroom Sink	Lead	4.73	ug/L		15	9/24/2016 11:44	10/13/2016 21:25	EPA 200.8	Drinking Water
S011883-23	Rm 112 Sink Basement	Lead	<0.50	ug/L		15	9/24/2016 11:48	10/13/2016 21:29	EPA 200.8	Drinking Water
S011883-24	Rm 319 Water Fountain 2nd FL	Lead	0.96	ug/L		15	9/24/2016 12:19	10/13/2016 21:31	EPA 200.8	Drinking Water
S011883-25	2nd FL Boys Old Wing Sink	Lead	19.4	ug/L		15	9/24/2016 12:29	10/13/2016 12:45	EPA 200.8	Drinking Water
S011883-26	Water Fountain 2 2nd FL	Lead	1.04	ug/L		15	9/24/2016 12:26	10/13/2016 21:33	EPA 200.8	Drinking Water
S011883-27	Sink Girls Bathroom New	Lead	<0.50	ug/L		15	9/24/2016 12:25	10/13/2016 21:35	EPA 200.8	Drinking Water
S011883-28	2nd FL Boys Sink 3	Lead	10.4	ug/L		15	9/24/2016 12:32	10/13/2016 12:47	EPA 200.8	Drinking Water
S011883-29	Rm 214 Water F. 1st FL	Lead	<0.50	ug/L		15	9/24/2016 12:15	10/13/2016 21:37	EPA 200.8	Drinking Water
S011883-30	3 Girl Sink Bathroom 1st FL	Lead	1.05	ug/L		15	9/24/2016 11:54	10/13/2016 21:40	EPA 200.8	Drinking Water

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603




SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Morse Elementary

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011883-31	Rm 320 Water F. 2nd FL	Lead	<0.50	ug/L		15	9/24/2016 12:17	10/13/2016 21:50	EPA 200.8	Drinking Water
S011883-32	Slop Sink 1st + 2nd FL	Lead	0.94	ug/L		15	9/24/2016 12:06	10/13/2016 21:52	EPA 200.8	Drinking Water
S011883-33	Boys Bathroom Sink 2 1st FL	Lead	0.54	ug/L		15	9/24/2016 12:05	10/13/2016 21:54	EPA 200.8	Drinking Water
S011883-34	1st Floor Room 216 Sink	Lead	0.99	ug/L		15	9/24/2016 12:16	10/13/2016 21:57	EPA 200.8	Drinking Water
S011883-35	1st Floor Girls BR Sink	Lead	<0.50	ug/L		15	9/24/2016 12:15	10/13/2016 21:59	EPA 200.8	Drinking Water
S011883-36	1st Floor Staff Room	Lead	3.46	ug/L		15	9/24/2016 12:07	10/13/2016 22:01	EPA 200.8	Drinking Water
S011883-37	1st Floor G Room 214 Sink	Lead	1.47	ug/L		15	9/24/2016 12:09	10/13/2016 22:03	EPA 200.8	Drinking Water
S011883-38	2nd Floor Room 320 Sink	Lead	1.09	ug/L		15	9/24/2016 12:11	10/13/2016 22:05	EPA 200.8	Drinking Water
S011883-39	1st Floor Staff Room	Lead	1.59	ug/L		15	9/24/2016 11:51	10/13/2016 22:07	EPA 200.8	Drinking Water
S011883-40	1st Floor Kitchen Sink 1	Lead	0.61	ug/L		15	9/24/2016 11:51	10/13/2016 22:10	EPA 200.8	Drinking Water
S011883-41	B/M Water F.	Lead	<0.50	ug/L		15	9/24/2016 11:25	10/13/2016 22:22	EPA 200.8	Drinking Water
S011883-42	B/M Slop Sink 2	Lead	1.96	ug/L		15	9/24/2016 11:40	10/13/2016 22:24	EPA 200.8	Drinking Water
S011883-43	Kitchen Bathroom	Lead	0.93	ug/L		15	9/24/2016 11:50	10/13/2016 22:27	EPA 200.8	Drinking Water
S011883-44	2 Sink Girls Bathroom Old	Lead	0.98	ug/L		15	9/24/2016 12:35	10/13/2016 22:29	EPA 200.8	Drinking Water
S011883-45	Staff Bathroom 2nd FL	Lead	2.04	ug/L		15	9/24/2016 12:33	10/13/2016 22:31	EPA 200.8	Drinking Water
S011883-46	1 Sink Girls Bathroom Old	Lead	2.21	ug/L		15	9/24/2016 12:35	10/13/2016 22:33	EPA 200.8	Drinking Water
S011883-47	2nd FL Boy Sink 2	Lead	47.0	ug/L		15	9/24/2016 12:31	10/13/2016 22:35	EPA 200.8	Drinking Water
S011883-48	Water Fountain 1 2nd FL	Lead	<0.50	ug/L		15	9/24/2016 12:31	10/13/2016 22:37	EPA 200.8	Drinking Water
S011883-49	Slop Sink 1 2nd FL	Lead	31.1	ug/L		15	9/24/2016 12:31	10/13/2016 22:39	EPA 200.8	Drinking Water
S011883-50	Slop Sink 2 2nd FL	Lead	4.79	ug/L		15	9/24/2016 12:26	10/13/2016 22:42	EPA 200.8	Drinking Water
S011883-51	Boys New Wing Sink 2nd FL	Lead	<0.50	ug/L		15	9/24/2016 12:26	10/13/2016 22:52	EPA 200.8	Drinking Water
S011883-52	3 Sink Girl Bathroom Old	Lead	0.78	ug/L		15	9/24/2016 12:35	10/13/2016 22:55	EPA 200.8	Drinking Water
S011883-53	RM 319 Sink 2nd FL	Lead	1.02	ug/L		15	9/24/2016 12:18	10/13/2016 22:57	EPA 200.8	Drinking Water
S011883-54	2nd FL Room 318 Water F.	Lead	<0.50	ug/L		15	9/24/2016 12:24	10/13/2016 22:59	EPA 200.8	Drinking Water
S011883-55	2nd FL Room 318 Sink	Lead	0.68	ug/L		15	9/24/2016 12:22	10/13/2016 23:01	EPA 200.8	Drinking Water
S011883-56	2nd FL Room 310 BR Sink	Lead	2.87	ug/L		15	9/24/2016 12:30	10/13/2016 23:03	EPA 200.8	Drinking Water
S011883-57	1st FL Water F. 2	Lead	<0.50	ug/L		15	9/24/2016 12:06	10/13/2016 23:05	EPA 200.8	Drinking Water
S011883-58	1st FL Boy Bathroom Sink	Lead	0.62	ug/L		15	9/24/2016 12:09	10/13/2016 23:07	EPA 200.8	Drinking Water
S011883-59	2nd FL Water F. Room 215	Lead	<0.50	ug/L		15	9/24/2016 12:16	10/13/2016 23:12	EPA 200.8	Drinking Water
S011883-60	2nd FL Room 215 Sink	Lead	1.99	ug/L		15	9/24/2016 12:15	10/13/2016 23:14	EPA 200.8	Drinking Water

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Morse Elementary

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011883-61	1st FL Boys BR Sink 1	Lead	0.64	ug/L		15	9/24/2016 12:05	10/13/2016 23:25	EPA 200.8	Drinking Water
S011883-62	1st FL Boys BR Sink 3	Lead	9.76	ug/L		15	9/24/2016 12:05	10/13/2016 23:27	EPA 200.8	Drinking Water
S011883-63	1st FL Water F. Rm 216	Lead	0.57	ug/L		15	9/24/2016 12:16	10/13/2016 23:29	EPA 200.8	Drinking Water

Lead analysis performed by ELAP #12406

Reviewed by

Dorothy DiNobile, Laboratory Director

Key: <=Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603




SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Smith Elementary

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011888-01	2nd Floor Teachers Room	Lead	2.93	ug/L		15	9/17/2016 11:22	10/14/2016 11:03	EPA 200.8	Drinking Water
S011888-02	2nd Floor Boys Rest Room #3	Lead	3.83	ug/L		15	9/17/2016 11:25	10/13/2016 12:26	EPA 200.8	Drinking Water
S011888-03	2nd Floor Boys Bathroom #1	Lead	1.33	ug/L		15	9/17/2016 11:25	10/14/2016 11:05	EPA 200.8	Drinking Water
S011888-04	2nd Floor Boys Bathroom #2	Lead	8.43	ug/L		15	9/17/2016 11:25	10/14/2016 11:07	EPA 200.8	Drinking Water
S011888-05	Hall Sink 1st Floor	Lead	<0.50	ug/L		15	9/17/2016 11:17	10/14/2016 11:09	EPA 200.8	Drinking Water
S011888-06	#3 Water Fountain 1st FL	Lead	<0.50	ug/L		15	9/17/2016 11:17	10/14/2016 11:11	EPA 200.8	Drinking Water
S011888-07	Boys Restroom Mop Sink 1st	Lead	27.8	ug/L		15	9/17/2016 11:17	10/13/2016 12:28	EPA 200.8	Drinking Water
S011888-08	Girls Bathroom 2 1st FL	Lead	11.2	ug/L		15	9/17/2016 11:19	10/14/2016 11:16	EPA 200.8	Drinking Water
S011888-09	Girls Bathroom 1 1st FL	Lead	2.15	ug/L		15	9/17/2016 11:20	10/14/2016 11:18	EPA 200.8	Drinking Water
S011888-10	Water Fountain 3rd Floor 2	Lead	<0.50	ug/L		15	9/17/2016 11:27	10/13/2016 18:43	EPA 200.8	Drinking Water
S011888-11	Rm 22 Sink #2	Lead	11.4	ug/L		15	9/17/2016 10:21	10/13/2016 12:31	EPA 200.8	Drinking Water
S011888-12	Basement FL Slop Sink Boys	Lead	1.48	ug/L		15	9/17/2016 10:20	10/13/2016 18:45	EPA 200.8	Drinking Water
S011888-13	Rm 22 Sink #1	Lead	4.34	ug/L		15	9/17/2016 10:20	10/13/2016 18:48	EPA 200.8	Drinking Water
S011888-14	Basement Boy Bathroom	Lead	0.53	ug/L		15	9/17/2016 10:20	10/13/2016 18:50	EPA 200.8	Drinking Water
S011888-15	Kitchen Basement	Lead	1.06	ug/L		15	9/17/2016 10:17	10/13/2016 18:54	EPA 200.8	Drinking Water
S011888-16	Basement East 1 Water F.	Lead	<0.50	ug/L		15	9/17/2016 10:16	10/13/2016 18:56	EPA 200.8	Drinking Water
S011888-17	2nd FL Girls Bathroom Sink	Lead	1.20	ug/L		15	9/17/2016 9:04	10/13/2016 18:58	EPA 200.8	Drinking Water
S011888-18	2 Girl Bathroom Kitchen	Lead	12.70	ug/L		15	9/17/2016 10:15	10/13/2016 19:00	EPA 200.8	Drinking Water
S011888-19	1 Girl Bathroom	Lead	803	ug/L		15	9/17/2016 10:15	10/13/2016 19:02	EPA 200.8	Drinking Water
S011888-20	East 2 Water Fountain	Lead	0.66	ug/L		15	9/17/2016 10:16	10/13/2016 19:04	EPA 200.8	Drinking Water
S011888-21	Kitchen Basement	Lead	0.79	ug/L		15	9/17/2016 10:17	10/13/2016 19:15	EPA 200.8	Drinking Water
S011888-22	Basement Mop Room	Lead	<0.50	ug/L		15	9/17/2016 10:18	10/13/2016 19:17	EPA 200.8	Drinking Water
S011888-23	Basement Restroom 2	Lead	<0.50	ug/L		15	9/17/2016 10:12	10/13/2016 19:19	EPA 200.8	Drinking Water
S011888-24	1 Water Fountain 1st	Lead	0.50	ug/L		15	9/17/2016 11:10	10/13/2016 19:21	EPA 200.8	Drinking Water
S011888-25	Classroom 2 Bathroom 1st FL	Lead	1.78	ug/L		15	9/17/2016 11:08	10/13/2016 19:23	EPA 200.8	Drinking Water
S011888-26	Principal Bathroom 1st FL	Lead	3.61	ug/L		15	9/17/2016 11:11	10/13/2016 19:26	EPA 200.8	Drinking Water
S011888-27	Nurse Bathroom 1st FL	Lead	1.38	ug/L		15	9/17/2016 11:13	10/13/2016 19:28	EPA 200.8	Drinking Water
S011888-28	Classroom 1st Bathroom 1st FL	Lead	1.34	ug/L		15	9/17/2016 11:05	10/13/2016 19:30	EPA 200.8	Drinking Water
S011888-29	Boys Bathroom Sink #2 1st FL	Lead	7.51	ug/L		15	9/17/2016 11:16	10/13/2016 19:32	EPA 200.8	Drinking Water
S011888-30	Staff Bathroom 2 1st FL	Lead	<0.50	ug/L		15	9/17/2016 11:15	10/13/2016 19:34	EPA 200.8	Drinking Water

Poughkeepsie City School District
 Jimmy McRay
 11 Collage Avenue
 Poughkeepsie, NY 12603



SMITH
 ENVIRONMENTAL
 LABORATORY

4 Scenic Drive
 Hyde Park, NY 12538
 845-229-6536
 NY ELAP ID: 10924

Poughkeepsie City School District - Smith Elementary

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011888-31	2nd FL Mops Bathroom	Lead	1.75	ug/L		15	9/17/2016 11:26	10/13/2016 19:47	EPA 200.8	Drinking Water
S011888-32	1 Boys Bathroom Sink	Lead	105	ug/L		15	9/17/2016 11:16	10/13/2016 19:49	EPA 200.8	Drinking Water
S011888-33	2nd Floor Water Fountain #2	Lead	<0.50	ug/L		15	9/17/2016 11:21	10/13/2016 19:51	EPA 200.8	Drinking Water
S011888-34	2nd Hall Sink 2nd FL	Lead	<0.50	ug/L		15	9/17/2016 11:21	10/13/2016 19:53	EPA 200.8	Drinking Water
S011888-35	2nd FL Girls Bathroom Sink 2	Lead	0.59	ug/L		15	9/17/2016 9:05	10/13/2016 19:55	EPA 200.8	Drinking Water
S011888-36	Boys Bathroom Basement	Lead	6.60	ug/L		15	9/17/2016 10:14	10/13/2016 19:57	EPA 200.8	Drinking Water
S011888-37	Teacher Bathroom 1	Lead	<0.50	ug/L		15	9/17/2016 10:11	10/13/2016 19:59	EPA 200.8	Drinking Water
S011888-38	2nd FL Girls Bathroom Sink 1	Lead	<0.50	ug/L		15	9/17/2016 9:01	10/13/2016 20:02	EPA 200.8	Drinking Water
S011888-39	Girl Bathroom Basement	Lead	1.19	ug/L		15	9/17/2016 10:20	10/13/2016 20:04	EPA 200.8	Drinking Water
S011888-40	Bathroom West Fountain	Lead	<0.50	ug/L		15	9/17/2016 10:21	10/13/2016 20:06	EPA 200.8	Drinking Water
S011888-41	Staff Bathroom Room 1 1st FL	Lead	<0.50	ug/L		15	9/17/2016 11:12	10/13/2016 20:16	EPA 200.8	Drinking Water
S011888-42	2 East Water Fountain 1st FL	Lead	<0.50	ug/L		15	9/17/2016 11:14	10/13/2016 20:19	EPA 200.8	Drinking Water
S011888-43	Nurse Office 1st FL	Lead	8.90	ug/L		15	9/17/2016 11:14	10/13/2016 20:21	EPA 200.8	Drinking Water
S011888-44	Teacher Bathroom 2	Lead	0.71	ug/L		15	9/17/2016 9:23	10/13/2016 20:23	EPA 200.8	Drinking Water

Lead analysis performed by ELAP #12406

Dorothy DiNobile

Key: <=Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Reviewed by
 Dorothy DiNobile, Laboratory Director

Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.

Poughkeepsie City School District
 Jimmy McRay
 11 Collage Avenue
 Poughkeepsie, NY 12603




SMITH
 ENVIRONMENTAL
 LABORATORY

4 Scenic Drive
 Hyde Park, NY 12538
 845-229-6536
 NY ELAP ID: 10924

Poughkeepsie City School District - Poughkeepsie High School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012554-01	Girl's Bathroom Sink-1, 1st Floor	Lead	1.34	ug/L		15	10/16/2016 9:21	11/2/2016 10:08	EPA 200.8	Drinking Water
S012554-02	Staff Cafe Wing	Lead	0.98	ug/L		15	10/16/2016 9:23	11/2/2016 10:10	EPA 200.8	Drinking Water
S012554-03	Boy Lockroom Sink-1	Lead	0.55	ug/L		15	10/16/2016 8:55	11/2/2016 10:12	EPA 200.8	Drinking Water
S012554-04	Main Office Sink	Lead	0.55	ug/L		15	10/16/2016 8:36	11/2/2016 10:15	EPA 200.8	Drinking Water
S012554-05	Hand Sink-2, Kitchen	Lead	3.43	ug/L		15	10/16/2016 9:55	11/2/2016 10:17	EPA 200.8	Drinking Water
S012554-06	Boy Cafe Wing Sink 2	Lead	1.19	ug/L		15	10/16/2016 9:22	11/2/2016 10:19	EPA 200.8	Drinking Water
S012554-07	Kitchen Prep Sink-2	Lead	<0.50	ug/L		15	10/16/2016 0:00	11/2/2016 10:21	EPA 200.8	Drinking Water
S012554-08	Staff Bathroom Sink-2	Lead	0.90	ug/L		15	10/16/2016 8:30	11/2/2016 10:24	EPA 200.8	Drinking Water
S012554-09	Kitchen Food Server Room	Lead	5.97	ug/L		15	10/16/2016 9:29	11/2/2016 10:26	EPA 200.8	Drinking Water
S012554-10	Music Bathroom Sink-1	Lead	1.19	ug/L		15	10/16/2016 9:14	11/2/2016 10:28	EPA 200.8	Drinking Water
S012554-11	Water F by Room 104	Lead	<0.50	ug/L		15	10/16/2016 8:35	11/2/2016 10:40	EPA 200.8	Drinking Water
S012554-12	Kitchen Dish Wash Sink-3	Lead	<0.50	ug/L		15	10/16/2016 9:27	11/2/2016 10:42	EPA 200.8	Drinking Water
S012554-13	Kitchen Dish Wash Sink-1	Lead	<0.50	ug/L		15	10/16/2016 8:47	11/2/2016 10:44	EPA 200.8	Drinking Water
S012554-14	Girl's Locker Room Sink-1	Lead	7.35	ug/L		15	10/16/2016 9:24	11/2/2016 10:46	EPA 200.8	Drinking Water
S012554-15	Girl's Bathroom Sink-2, 1st Floor	Lead	1.20	ug/L		15	10/16/2016 9:14	11/2/2016 10:49	EPA 200.8	Drinking Water
S012554-16	Girl's Bathroom Sink-3	Lead	1.75	ug/L		15	10/16/2016 0:00	11/2/2016 10:51	EPA 200.8	Drinking Water
S012554-17	Gym Entrance Sink	Lead	3.57	ug/L		15	10/16/2016 8:46	11/2/2016 10:53	EPA 200.8	Drinking Water
S012554-18	Gym Water F	Lead	<0.50	ug/L		15	10/16/2016 8:54	11/2/2016 10:56	EPA 200.8	Drinking Water




Poughkeepsie City School District - Poughkeepsie High School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012554-19	Room 125 Sink Girls	Lead	1.93	ug/L		15	10/16/2016 9:22	11/2/2016 11:00	EPA 200.8	Drinking Water
S012554-20	Boy Locker Room Water F	Lead	32.5	ug/L		15	10/16/2016 0:00	11/2/2016 11:02	EPA 200.8	Drinking Water
S012554-21	Boy's Bathroom Sink-2	Lead	0.70	ug/L		15	10/16/2016 9:08	11/2/2016 11:14	EPA 200.8	Drinking Water
S012554-22	Boy's Bathroom Sink-2	Lead	5.50	ug/L		15	10/16/2016 9:20	11/2/2016 11:16	EPA 200.8	Drinking Water
S012554-23	Kitchen Steam Ketter	Lead	1.43	ug/L		15	10/16/2016 9:32	11/2/2016 11:18	EPA 200.8	Drinking Water
S012554-24	Staff Bathroom 1st Floor	Lead	3.08	ug/L		15	10/16/2016 8:30	11/2/2016 11:21	EPA 200.8	Drinking Water
S012554-25	Girls Bathroom Sink 3, 1st Floor	Lead	1.65	ug/L		15	10/16/2016 8:40	11/2/2016 11:23	EPA 200.8	Drinking Water
S012554-26	Water F Next Room 5, 1st Floor	Lead	<0.50	ug/L		15	10/16/2016 9:13	11/2/2016 11:25	EPA 200.8	Drinking Water
S012554-27	Music Wing Sink-1	Lead	1.49	ug/L		15	10/16/2016 9:14	11/2/2016 11:27	EPA 200.8	Drinking Water
S012554-28	Dish Wash Sink 2	Lead	3.78	ug/L		15	10/16/2016 9:27	11/2/2016 11:30	EPA 200.8	Drinking Water
S012554-29	Nurse Office	Lead	88.4	ug/L		15	10/16/2016 0:00	11/2/2016 11:32	EPA 200.8	Drinking Water
S012554-30	Boys Locker Room Water F	Lead	48.8	ug/L		15	10/16/2016 8:55	11/2/2016 11:34	EPA 200.8	Drinking Water
S012554-31	Slop Sink	Lead	22.3	ug/L		15	10/17/2016 9:31	11/2/2016 12:01	EPA 200.8	Drinking Water
S012554-32	Outside	Lead	0.86	ug/L		15	10/17/2016 9:34	11/2/2016 12:03	EPA 200.8	Drinking Water
S012554-33	Field House Sink	Lead	1.20	ug/L		15	10/17/2016 9:30	11/2/2016 12:05	EPA 200.8	Drinking Water
S012554-34	Boys 1st Floor Center Sink-1	Lead	0.78	ug/L		15	10/16/2016 9:08	11/2/2016 12:07	EPA 200.8	Drinking Water
S012554-35	Main Office Sink	Lead	0.81	ug/L		15	10/16/2016 8:36	11/2/2016 12:10	EPA 200.8	Drinking Water
S012554-36	Water F by Room 104	Lead	<0.50	ug/L		15	10/16/2016 8:35	11/2/2016 12:12	EPA 200.8	Drinking Water



Poughkeepsie City School District - Poughkeepsie High School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012554-37	Water F 1st Floor 4	Lead	<0.50	ug/L		15	10/16/2016 8:39	11/2/2016 12:14	EPA 200.8	Drinking Water
S012554-38	Boys Listroom Maysk Sink 1	Lead	0.85	ug/L		15	10/16/2016 8:24	11/2/2016 12:17	EPA 200.8	Drinking Water
S012554-39	Girls Bathroom Sink-2, 1st Floor	Lead	0.77	ug/L		15	10/16/2016 8:26	11/2/2016 12:19	EPA 200.8	Drinking Water
S012554-40	Boy Mayst Sink 2	Lead	1.03	ug/L		15	10/16/2016 8:24	11/2/2016 12:21	EPA 200.8	Drinking Water
S012554-41	Water F #3, 1st Floor	Lead	<0.50	ug/L		15	10/16/2016 8:37	11/2/2016 12:33	EPA 200.8	Drinking Water
S012554-42	Water F #6, 1st Floor	Lead	<0.50	ug/L		15	10/16/2016 9:13	11/2/2016 12:35	EPA 200.8	Drinking Water
S012554-43	Girls Bathroom Sink-3, 1st Floor	Lead	2.76	ug/L		15	10/16/2016 8:20	11/2/2016 12:37	EPA 200.8	Drinking Water
S012554-44	Boys Bathroom Sink-1, 1st Floor	Lead	1.02	ug/L		15	10/16/2016 8:40	11/2/2016 12:39	EPA 200.8	Drinking Water
S012554-45	Women Gym Office	Lead	2.42	ug/L		15	10/16/2016 8:45	11/2/2016 12:42	EPA 200.8	Drinking Water
S012554-46	Principal East Room	Lead	3.58	ug/L		15	10/16/2016 8:37	11/2/2016 12:44	EPA 200.8	Drinking Water
S012554-47	Kitchen Dishroom Hand	Lead	0.65	ug/L		15	10/16/2016 0:00	11/2/2016 12:46	EPA 200.8	Drinking Water
S012554-48	Kitchen Foodprep Sink	Lead	<0.50	ug/L		15	10/16/2016 9:28	11/2/2016 12:49	EPA 200.8	Drinking Water
S012554-49	Kitchen Sink	Lead	0.76	ug/L		15	10/16/2016 9:32	11/2/2016 12:53	EPA 200.8	Drinking Water
S012554-50	11 Grade AP Office	Lead	6.73	ug/L		15	10/16/2016 10:56	11/2/2016 12:55	EPA 200.8	Drinking Water
S012554-51	Boys Bathroom Sink-1, 1st Floor	Lead	<0.50	ug/L		15	10/16/2016 9:20	11/2/2016 13:07	EPA 200.8	Drinking Water
S012554-52	Nurse Office	Lead	2.09	ug/L		15	10/16/2016 0:00	11/2/2016 13:09	EPA 200.8	Drinking Water
S012554-53	Girls Locker Room Water F	Lead	1.69	ug/L		15	10/16/2016 0:00	11/2/2016 13:11	EPA 200.8	Drinking Water
S012554-54	Staff Bathroom Sink-1, 2nd Floor	Lead	0.79	ug/L		15	10/16/2016 10:03	11/2/2016 13:14	EPA 200.8	Drinking Water




Poughkeepsie City School District - Poughkeepsie High School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012554-55	Trainer Office	Lead	12.4	ug/L		15	10/16/2016 10:15	11/2/2016 13:16	EPA 200.8	Drinking Water
S012554-56	12 Grade Office Bathroom	Lead	<0.50	ug/L		15	10/16/2016 10:00	11/2/2016 13:18	EPA 200.8	Drinking Water
S012554-57	Girls Bathroom Sink 2, 2nd Floor	Lead	2.43	ug/L		15	10/16/2016 9:47	11/2/2016 13:21	EPA 200.8	Drinking Water
S012554-58	Staff Bathroom Sink 2, 2st Floor	Lead	1.63	ug/L		15	10/16/2016 10:41	11/2/2016 13:23	EPA 200.8	Drinking Water
S012554-59	Water F #6, 2nd Floor	Lead	<0.50	ug/L		15	10/16/2016 10:45	11/2/2016 13:25	EPA 200.8	Drinking Water
S012554-60	Girls Bathroom Sink-3, 2nd Floor	Lead	2.85	ug/L		15	10/16/2016 9:47	11/2/2016 13:27	EPA 200.8	Drinking Water
S012554-61	Staff Bathroom Sink-1, 2nd Floor	Lead	0.55	ug/L		15	10/16/2016 10:03	11/2/2016 13:39	EPA 200.8	Drinking Water
S012554-62	Girls Bathroom Sink-1, 2nd Floor	Lead	1.87	ug/L		15	10/16/2016 0:00	11/2/2016 13:41	EPA 200.8	Drinking Water
S012554-63	Staff Men Sink-1, 2nd Floor	Lead	1.10	ug/L		15	10/16/2016 10:49	11/2/2016 13:43	EPA 200.8	Drinking Water
S012554-64	Gym Caff	Lead	15.6	ug/L		15	10/16/2016 9:47	11/2/2016 13:46	EPA 200.8	Drinking Water
S012554-65	Girls Locker Room Sink 2	Lead	2.14	ug/L		15	10/16/2016 9:47	11/2/2016 13:50	EPA 200.8	Drinking Water
S012554-66	Girls Locker Room Water F	Lead	3.76	ug/L		15	10/16/2016 9:47	11/2/2016 13:53	EPA 200.8	Drinking Water
S012554-67	Kitchen Store Room Sink White	Lead	34.5	ug/L		15	10/16/2016 9:39	11/2/2016 13:55	EPA 200.8	Drinking Water
S012554-68	Staff Bathroom, 2nd Floor	Lead	3.83	ug/L		15	10/16/2016 10:01	11/2/2016 13:57	EPA 200.8	Drinking Water
S012554-69	Girls Bathroom Sink 1, 2nd Floor	Lead	1.32	ug/L		15	10/16/2016 9:47	11/2/2016 13:59	EPA 200.8	Drinking Water
S012554-70	Gym Water F	Lead	1.43	ug/L		15	10/16/2016 8:45	11/2/2016 14:02	EPA 200.8	Drinking Water
S012554-71	Boys Bathroom Sink-1, 2nd Floor	Lead	0.57	ug/L		15	10/16/2016 10:32	11/2/2016 14:13	EPA 200.8	Drinking Water
S012554-72	Gym PE Office Bathroom	Lead	1.46	ug/L		15	10/16/2016 0:00	11/2/2016 14:15	EPA 200.8	Drinking Water

Poughkeepsie City School DistrictJimmy McRay
11 Collage Avenue

Poughkeepsie, NY 12603

**SMITH**
ENVIRONMENTAL
LABORATORY4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924**Poughkeepsie City School District - Poughkeepsie High School**

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012554-73	Girls Bathroom Sink 3, 2nd Floor	Lead	2.14	ug/L		15	10/16/2016 10:03	11/2/2016 14:18	EPA 200.8	Drinking Water
S012554-74	Girl's Bathroom Sink-1, 1st Floor	Lead	2.07	ug/L		15	10/16/2016 8:40	11/2/2016 14:20	EPA 200.8	Drinking Water
S012554-75	Girl's Bathroom Sink-2, 2nd Floor	Lead	1.94	ug/L		15	10/16/2016 10:05	11/2/2016 14:22	EPA 200.8	Drinking Water
S012554-76	Main Office Women	Lead	2.22	ug/L		15	10/16/2016 8:32	11/2/2016 14:25	EPA 200.8	Drinking Water
S012554-77	Kitchen Steam Hose	Lead	3.14	ug/L		15	10/16/2016 9:30	11/2/2016 14:27	EPA 200.8	Drinking Water
S012554-78	Water F 1, 2nd Floor	Lead	<0.50	ug/L		15	10/16/2016 9:30	11/2/2016 14:29	EPA 200.8	Drinking Water
S012554-79	Boys Bathroom Sink-1, 2nd Floor	Lead	<0.50	ug/L		15	10/16/2016 9:51	11/2/2016 14:32	EPA 200.8	Drinking Water
S012554-80	Water F #5, 2nd Floor	Lead	<0.50	ug/L		15	10/16/2016 10:45	11/2/2016 14:34	EPA 200.8	Drinking Water
S012554-81	Water F #4, 2nd Floor	Lead	<0.50	ug/L		15	10/16/2016 10:12	11/2/2016 14:48	EPA 200.8	Drinking Water
S012554-82	Staff Room, 2nd Floor, Sink 2	Lead	1.34	ug/L		15	10/16/2016 10:44	11/2/2016 14:50	EPA 200.8	Drinking Water
S012554-83	Boy Bathroom, Cafe Wing, Sink 1	Lead	0.76	ug/L		15	10/16/2016 9:22	11/2/2016 14:52	EPA 200.8	Drinking Water
S012554-84	Girls Bathroom Room 125 Sink	Lead	4.45	ug/L		15	10/16/2016 9:17	11/2/2016 14:55	EPA 200.8	Drinking Water
S012554-85	Boys Bathroom Sink #2, 1st Floor	Lead	0.93	ug/L		15	10/16/2016 8:40	11/2/2016 14:57	EPA 200.8	Drinking Water
S012554-86	Girls #2, 2nd Floor Sink	Lead	0.63	ug/L		15	10/16/2016 8:35	11/2/2016 14:59	EPA 200.8	Drinking Water
S012554-87	Girls Bathroom Sink-2, 1st Floor	Lead	2.07	ug/L		15	10/16/2016 8:40	11/2/2016 15:01	EPA 200.8	Drinking Water
S012554-88	Kitchen Bathroom	Lead	<0.50	ug/L		15	10/16/2016 9:30	11/2/2016 15:04	EPA 200.8	Drinking Water
S012554-89	Water F-2, 2nd Floor	Lead	1.12	ug/L		15	10/16/2016 9:50	11/2/2016 15:06	EPA 200.8	Drinking Water
S012554-90	Water F-3, 2nd Floor	Lead	<0.50	ug/L		15	10/16/2016 10:02	11/2/2016 15:08	EPA 200.8	Drinking Water

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Poughkeepsie High School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012554-91	Room 125 Sink 3	Lead	0.62	ug/L		15	10/16/2016 9:12	11/2/2016 15:20	EPA 200.8	Drinking Water
S012554-92	Boy Bathroom Sink 2, 2nd Floor	Lead	3.05	ug/L		15	10/16/2016 10:37	11/2/2016 15:22	EPA 200.8	Drinking Water
S012554-93	Main Office	Lead	2.22	ug/L		15	10/16/2016 8:37	11/2/2016 15:25	EPA 200.8	Drinking Water

Lead analysis performed by ELAP #12406

Reviewed by

Dorothy DiNobile, Laboratory Director

Key: <=Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Poughkeepsie Middle School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012626-01	Womens Bathroom, Staff	Lead	0.79	ug/L		15	10/16/2016 11:15	11/10/2016 18:58	EPA 200.8	Drinking Water
S012626-02	Boys Locker Room Sink-2	Lead	1.86	ug/L		15	10/16/2016 0:00	11/10/2016 19:00	EPA 200.8	Drinking Water
S012626-03	Girls Bathroom Center Basement	Lead	<0.50	ug/L		15	10/16/2016 0:00	11/10/2016 19:03	EPA 200.8	Drinking Water
S012626-04	Asst. Principal Office 1st Floor	Lead	4.88	ug/L		15	10/16/2016 0:00	11/10/2016 19:05	EPA 200.8	Drinking Water
S012626-05	Restroom Sink-2 Basement	Lead	327	ug/L		15	10/16/2016 11:22	11/10/2016 19:07	EPA 200.8	Drinking Water
S012626-06	Boy Bathroom Sink-1	Lead	0.57	ug/L		15	10/16/2016 11:35	11/10/2016 19:09	EPA 200.8	Drinking Water
S012626-07	Room 121 Sink	Lead	2.87	ug/L		15	10/16/2016 0:00	11/10/2016 19:11	EPA 200.8	Drinking Water
S012626-08	Water F 2 3rd Floor	Lead	<0.50	ug/L		15	10/16/2016 14:25	11/10/2016 19:13	EPA 200.8	Drinking Water
S012626-09	Basement Water F	Lead	<0.50	ug/L		15	10/16/2016 11:15	11/10/2016 19:15	EPA 200.8	Drinking Water
S012626-10	Boys Bathroom Sink-3	Lead	0.67	ug/L		15	10/16/2016 11:32	11/10/2016 19:17	EPA 200.8	Drinking Water
S012626-11	Room 107 Water F	Lead	2.63	ug/L		15	10/16/2016 13:24	11/10/2016 19:28	EPA 200.8	Drinking Water
S012626-12	Nurse Bathroom Sink	Lead	<0.50	ug/L		15	10/16/2016 0:00	11/10/2016 19:30	EPA 200.8	Drinking Water
S012626-13	Girls Locker Room Office	Lead	1.53	ug/L		15	10/16/2016 11:24	11/10/2016 19:32	EPA 200.8	Drinking Water
S012626-14	Girls Bathroom Sink-2 1st Floor	Lead	<0.50	ug/L		15	10/16/2016 13:30	11/10/2016 19:34	EPA 200.8	Drinking Water
S012626-15	Room 101 Sink	Lead	23.8	ug/L		15	10/16/2016 11:15	11/10/2016 19:36	EPA 200.8	Drinking Water
S012626-16	Water F 2 1st Floor	Lead	<0.50	ug/L		15	10/16/2016 13:25	11/10/2016 19:38	EPA 200.8	Drinking Water
S012626-17	Water F Room 117	Lead	3.28	ug/L		15	10/16/2016 11:17	11/10/2016 19:40	EPA 200.8	Drinking Water
S012626-18	Girls Bathroom Center Sink	Lead	1.17	ug/L		15	10/16/2016 11:49	11/10/2016 19:42	EPA 200.8	Drinking Water
S012626-19	Principal Office	Lead	3.02	ug/L		15	10/16/2016 12:21	11/10/2016 19:47	EPA 200.8	Drinking Water
S012626-20	Girls Bathroom Sink-4	Lead	0.81	ug/L		15	10/16/2016 11:45	11/10/2016 19:49	EPA 200.8	Drinking Water
S012626-21	Room 106 Sink	Lead	31.6	ug/L		15	10/16/2016 13:15	11/10/2016 19:59	EPA 200.8	Drinking Water
S012626-22	AP Office 2nd Floor	Lead	1.89	ug/L		15	10/16/2016 0:00	11/10/2016 20:01	EPA 200.8	Drinking Water
S012626-23	Kitchen Pot Sink-2	Lead	<0.50	ug/L		15	10/16/2016 11:50	11/10/2016 20:03	EPA 200.8	Drinking Water
S012626-24	Kitchen Sink 1 By Door	Lead	1.19	ug/L		15	10/16/2016 0:00	11/10/2016 20:05	EPA 200.8	Drinking Water
S012626-26	Kitchen Sink-2	Lead	1.60	ug/L		15	10/16/2016 0:00	11/10/2016 20:08	EPA 200.8	Drinking Water
S012626-27	Boys Bathroom Sink-1 1st Floor	Lead	4.54	ug/L		15	10/16/2016 13:01	11/10/2016 20:10	EPA 200.8	Drinking Water
S012626-28	Room 112 Sink	Lead	2.65	ug/L		15	10/16/2016 12:26	11/10/2016 20:12	EPA 200.8	Drinking Water
S012626-29	North Wing Sink-4	Lead	13.2	ug/L		15	10/16/2016 11:21	11/10/2016 20:14	EPA 200.8	Drinking Water
S012626-30	Girls Locker Room Bathroom	Lead	0.72	ug/L		15	10/16/2016 11:25	11/10/2016 20:16	EPA 200.8	Drinking Water
S012626-31	Water F 2nd Floor 2	Lead	<0.50	ug/L		15	10/16/2016 0:00	11/10/2016 20:18	EPA 200.8	Drinking Water

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Poughkeepsie Middle School

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012626-32	Mens Staff Room Bathroom	Lead	1.69	ug/L		15	10/16/2016 11:15	11/10/2016 20:29	EPA 200.8	Drinking Water
S012626-33	Mens Bathroom Sink 2nd Floor	Lead	1.01	ug/L		15	10/16/2016 14:05	11/10/2016 20:31	EPA 200.8	Drinking Water
S012626-34	Girls Bathroom Sink-1 2nd Floor	Lead	0.65	ug/L		15	10/16/2016 14:05	11/10/2016 20:33	EPA 200.8	Drinking Water
S012626-35	Basement Boys Bathroom Sink 1	Lead	<0.50	ug/L		15	10/16/2016 11:33	11/10/2016 20:35	EPA 200.8	Drinking Water
S012626-36	Girls Bathroom Sink-2 Main	Lead	1.53	ug/L		15	10/16/2016 12:17	11/10/2016 20:39	EPA 200.8	Drinking Water
S012626-37	Boys Bathroom Sink-1 1st Floor	Lead	<0.50	ug/L		15	10/16/2016 13:25	11/10/2016 20:41	EPA 200.8	Drinking Water
S012626-38	Girls Bathroom Sink-4 1st Floor	Lead	1.45	ug/L		15	10/16/2016 13:05	11/10/2016 20:43	EPA 200.8	Drinking Water
S012626-39	Girls Bathroom Sink-3 1st Floor	Lead	1.41	ug/L		15	10/16/2016 13:05	11/10/2016 20:45	EPA 200.8	Drinking Water
S012626-40	Room 104 Sink	Lead	14.3	ug/L		15	10/16/2016 13:22	11/10/2016 20:48	EPA 200.8	Drinking Water
S012626-41	Room 114 Water F	Lead	6.00	ug/L		15	10/16/2016 12:54	11/10/2016 20:50	EPA 200.8	Drinking Water
S012626-42	Main Lobby Sink-1	Lead	<0.50	ug/L		15	10/16/2016 12:15	11/10/2016 21:00	EPA 200.8	Drinking Water
S012626-43	Room 115 Water F	Lead	32.7	ug/L		15	10/16/2016 12:30	11/10/2016 21:02	EPA 200.8	Drinking Water
S012626-44	Room 118 Water F	Lead	7.32	ug/L		15	10/16/2016 12:26	11/10/2016 21:04	EPA 200.8	Drinking Water
S012626-45	Room 108 Sink	Lead	32.7	ug/L		15	10/16/2016 13:26	11/10/2016 21:07	EPA 200.8	Drinking Water
S012626-46	Main Office Staff	Lead	<0.50	ug/L		15	10/16/2016 12:22	11/10/2016 21:09	EPA 200.8	Drinking Water
S012626-47	Girls Bathroom Sink-4 1st Floor	Lead	<0.50	ug/L		15	10/16/2016 13:20	11/10/2016 21:11	EPA 200.8	Drinking Water
S012626-48	Room 114 Sink	Lead	7.17	ug/L		15	10/16/2016 12:54	11/10/2016 21:13	EPA 200.8	Drinking Water
S012626-49	Room 018 Sink	Lead	2.65	ug/L		15	10/16/2016 11:35	11/10/2016 21:15	EPA 200.8	Drinking Water
S012626-50	Girls Locker Room Sink-2	Lead	0.90	ug/L		15	10/16/2016 11:25	11/10/2016 21:17	EPA 200.8	Drinking Water
S012626-51	Boys Bathroom Sink-4	Lead	0.89	ug/L		15	10/16/2016 11:37	11/10/2016 21:19	EPA 200.8	Drinking Water

Lead analysis performed by ELAP #12406

Dorothy DiNobile

Reviewed by
Dorothy DiNobile, Laboratory Director

Key: <=Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.

Poughkeepsie City School District
Jimmy McRay
11 Collage Avenue
Poughkeepsie, NY 12603



4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Poughkeepsie City School District - Warring Elementary

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011885-01	1 Water Fountain 1st FL	Lead	<0.50	ug/L		15	9/18/2016 8:27	10/12/2016 17:56	EPA 200.8	Drinking Water
S011885-02	3 Sink Girls Bathroom 1st FL	Lead	0.88	ug/L		15	9/18/2016 8:30	10/12/2016 18:00	EPA 200.8	Drinking Water
S011885-03	2 Sink Boy Bathroom 2nd	Lead	1.19	ug/L		15	9/18/2016 8:30	10/12/2016 18:03	EPA 200.8	Drinking Water
S011885-04	1 Sink Girls Bathroom 1st FL	Lead	<0.50	ug/L		15	9/18/2016 8:30	10/12/2016 18:14	EPA 200.8	Drinking Water
S011885-05	3 Sink Girls 2nd FL	Lead	0.74	ug/L		15	9/18/2016 8:34	10/12/2016 18:16	EPA 200.8	Drinking Water
S011885-06	Staff Restroom 2nd FL	Lead	<0.50	ug/L		15	9/18/2016 8:38	10/12/2016 18:19	EPA 200.8	Drinking Water
S011885-07	4 Sink Girls 2nd FL	Lead	1.01	ug/L		15	9/18/2016 8:35	10/12/2016 18:21	EPA 200.8	Drinking Water
S011885-08	3 Sink Boys Bathroom 2nd	Lead	1.30	ug/L		15	9/18/2016 8:35	10/12/2016 18:23	EPA 200.8	Drinking Water
S011885-09	RM 17 2nd FL	Lead	54.3	ug/L		15	9/18/2016 8:27	10/13/2016 12:20	EPA 200.8	Drinking Water
S011885-10	1 Sink Boy Bathroom 2nd	Lead	2.05	ug/L		15	9/18/2016 8:35	10/12/2016 18:25	EPA 200.8	Drinking Water
S011885-11	Staff Restroom 1st FL	Lead	2.67	ug/L		15	9/18/2016 8:27	10/12/2016 18:28	EPA 200.8	Drinking Water
S011885-12	2 Water Fountain 1st FL	Lead	<0.50	ug/L		15	9/18/2016 8:26	10/12/2016 18:30	EPA 200.8	Drinking Water
S011885-13	Staff Restroom Basement	Lead	0.92	ug/L		15	9/18/2016 8:21	10/12/2016 18:32	EPA 200.8	Drinking Water
S011885-14	Water Fountain Basement	Lead	<0.50	ug/L		15	9/18/2016 8:26	10/12/2016 18:34	EPA 200.8	Drinking Water
S011885-15	Boy Bathroom Basement	Lead	<0.50	ug/L		15	9/18/2016 8:25	10/12/2016 18:46	EPA 200.8	Drinking Water
S011885-16	Girl Bathroom Basement	Lead	1.55	ug/L		15	9/18/2016 8:25	10/12/2016 18:48	EPA 200.8	Drinking Water
S011885-17	Storage Basement	Lead	13.3	ug/L		15	9/18/2016 8:20	10/12/2016 18:50	EPA 200.8	Drinking Water
S011885-18	1 Sink Kitchen Basement	Lead	1.41	ug/L		15	9/18/2016 8:20	10/12/2016 18:53	EPA 200.8	Drinking Water
S011885-19	2 Sink Kitchen Basement	Lead	1.96	ug/L		15	9/18/2016 8:20	10/12/2016 18:57	EPA 200.8	Drinking Water
S011885-20	4 Sink Girls Bathroom 1st FL	Lead	1.37	ug/L		15	9/18/2016 8:30	10/12/2016 19:00	EPA 200.8	Drinking Water
S011885-21	1 Sink Girls 2nd FL	Lead	0.72	ug/L		15	9/18/2016 8:37	10/12/2016 19:02	EPA 200.8	Drinking Water
S011885-22	2 Sink Girls 2nd FL	Lead	0.65	ug/L		15	9/18/2016 8:37	10/12/2016 19:04	EPA 200.8	Drinking Water
S011885-23	Water Fountain 2nd FL	Lead	<0.50	ug/L		15	9/18/2016 8:37	10/12/2016 19:06	EPA 200.8	Drinking Water
S011885-24	Room 2 1st FL	Lead	0.70	ug/L		15	9/18/2016 8:30	10/12/2016 19:09	EPA 200.8	Drinking Water
S011885-25	2 Sink Girls Bathroom 1st FL	Lead	2.07	ug/L		15	9/18/2016 8:30	10/13/2016 11:25	EPA 200.8	Drinking Water

Lead analysis performed by ELAP #12406

Dorothy DiNobile

Key: <=Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Reviewed by
Dorothy DiNobile, Laboratory Director

Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.