

ANALYTICAL REPORT

Job Number: 420-207104-1

SDG Number: Poughkeepsie Middle School (PMS)

Job Description: Poughkeepsie City School

For:

Poughkeepsie City Schools

18 S Perry St

Poughkeepsie, NY 12601

Attention: Susan Stevens



Mary Hernandez

Customer Service Manager

reports@envirotestlaboratories.com

10/22/2021

cc: Ms. Renee Cusack

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at Envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

METHOD SUMMARY

Client: Poughkeepsie City Schools

Job Number: 420-207104-1
SDG Number: Poughkeepsie Middle School (PMS)

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: kitchen storage BR
Lab Sample ID: 420-207104-1

Date Sampled: 09/18/2021 0921
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1144	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	0.0010	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: WF near kitchen
Lab Sample ID: 420-207104-2

Date Sampled: 09/18/2021 0923
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution	
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1146		
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000		
Lead	0.023	g	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: kitchen sink 1
Lab Sample ID: 420-207104-3

Date Sampled: 09/18/2021 0925
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1148	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	<0.0010	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: kitchen sink 3
Lab Sample ID: 420-207104-4

Date Sampled: 09/18/2021 0928
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/27/2021 1155	
Prep Method: 200.7/200.8			Date Prepared:	09/24/2021 1000	
Lead	<0.0010	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: lobby water
Lab Sample ID: 420-207104-5

Date Sampled: 09/18/2021 0933
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1157	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	<0.0010	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: kitchen hand sink
Lab Sample ID: 420-207104-6

Date Sampled: 09/18/2021 0937
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021 1159		
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021 1000		
Lead	0.0011	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: main office WF
Lab Sample ID: 420-207104-7

Date Sampled: 09/18/2021 0940
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1201	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	0.067 g	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: main office sink
Lab Sample ID: 420-207104-8

Date Sampled: 09/18/2021 0941
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1203	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	<0.0010	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: Rm 104
Lab Sample ID: 420-207104-9

Date Sampled: 09/18/2021 0945
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1205	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	0.011	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: Rm 103
Lab Sample ID: 420-207104-10

Date Sampled: 09/18/2021 0946
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1214	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	0.0022	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: WF east wing
Lab Sample ID: 420-207104-11

Date Sampled: 09/18/2021 0948
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/27/2021 1220	
Prep Method: 200.7/200.8			Date Prepared:	09/24/2021 1000	
Lead	<0.0010	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: 101 sink
Lab Sample ID: 420-207104-12

Date Sampled: 09/18/2021 0953
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1222	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	0.0013	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: 102 sink
Lab Sample ID: 420-207104-13

Date Sampled: 09/18/2021 0954
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/27/2021 1225	
Prep Method: 200.7/200.8			Date Prepared:	09/24/2021 1000	
Lead	<0.0010	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: 110 sink
Lab Sample ID: 420-207104-14

Date Sampled: 09/18/2021 0956
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1227	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	0.0016	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: nurse sink
Lab Sample ID: 420-207104-15

Date Sampled: 09/18/2021 0959
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1229	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	<0.0010	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: 113 sink
Lab Sample ID: 420-207104-16

Date Sampled: 09/18/2021 1001
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1231	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	0.0067	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: 120 sink
Lab Sample ID: 420-207104-17

Date Sampled: 09/18/2021 1003
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1233	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	0.14 g	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: gym WF
Lab Sample ID: 420-207104-18

Date Sampled: 09/18/2021 1007
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/27/2021	1235	
Prep Method: 200.7/200.8			Date Prepared: 09/24/2021	1000	
Lead	0.0026	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: 2nd Fl east WF
Lab Sample ID: 420-207104-19

Date Sampled: 09/18/2021 1012
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/27/2021 1238	
Prep Method: 200.7/200.8			Date Prepared:	09/24/2021 1000	
Lead	<0.0010	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: 2nd north WF
Lab Sample ID: 420-207104-20

Date Sampled: 09/18/2021 1014
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/27/2021 1246	
Prep Method: 200.7/200.8			Date Prepared:	09/24/2021 1000	
Lead	<0.0010	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: 3rd Fl east WF
Lab Sample ID: 420-207104-21

Date Sampled: 09/18/2021 1019
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/03/2021 1721	
Prep Method: 200.7/200.8			Date Prepared:	10/01/2021 1600	
Lead	<0.0010	mg/L	0.0010	0.0010	1.0

Susan Stevens
Poughkeepsie City Schools
18 S Perry St
Poughkeepsie, NY 12601

Job Number: 420-207104-1
Sdg Number: Poughkeepsie Middle School (PMS)

Client Sample ID: 3rd FI north WF
Lab Sample ID: 420-207104-22

Date Sampled: 09/18/2021 1021
Date Received: 09/22/2021 1615
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 09/29/2021 1833		
Prep Method: 200.7/200.8			Date Prepared: 09/27/2021 0919		
Lead	0.074 g	mg/L	0.0010	0.0010	1.0

DATA REPORTING QUALIFIERS

Client: Poughkeepsie City Schools

Job Number:
Sdg Number: Poughkeepsie Middle School (PMS)

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards

Certification Information

Client: Poughkeepsie City Schools

Job Number:

Sdg Number: Poughkeepsie Middle School (PMS)

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Settable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Poughkeepsie City Schools

Job Number:

Sdg Number: Poughkeepsie Middle School (PMS)

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points


CHAIN OF CUSTODY

REPORT# (Lab Use Only)

Lab Name **EnviroTest Laboratories** NYS DOH LAB # 10142 NJDEP LAB # NY105 CT DOPH# PH-0654
 Lab Address **316 Fullerton Avenue, Newburgh, NY 12550** Phone (845) 562-0890
 Field Office Address **312 Titusville Rd, Poughkeepsie, NY 12603** Field Office Phone (845) 229-6536

~~207096~~, 1 of 2
207104

****IMPORTANT NOTE: All services performed by Envirotest Laboratories LLC are subject to our Terms & Conditions available at <http://www.envirotestlabs.com/terms>** Any Rush TAT must be approved in advance by lab****

CLIENT NAME Poughkeepsie City Schools		PWS NUMBER	MATRIX TYPE	 420-207104-B-22 3rd Fl north WF Date Sampled: 9/18/2021 420-1785515	TURNAROUND TIME (Biz Days) _____ NON-TESTING CHARGES _____ NORMAL _____ P/U _____ SAMP _____ RUSH (Y/N) _____ GRAB _____ COMP _____ RUSH (# Biz Days) _____ REPORTING _____ #OF COOLERS _____ OTHER _____
CLIENT ADDRESS 18 So. Perry St Poughkeepsie, NY 12601					
CLIENT PHONE (845) 451-4996	CLIENT (SITE) CONTACT Marcos Rodriguez		Total # of Containers 40 mL _____ 40mL Vials HCl _____ 40mL Vials Sulfuric _____ 250mL Plastic _____ 250 mL Plastic Nitric Acid _____ 250mL Plastic Sulfuric A _____ 250mL Plastic Sodium H _____ 250 Amber Sulfuric _____ Liter Plastic _____ Liter Amber Glass _____ Liter Amber HCl _____ 125 mL Sterile Sodium I _____ 125mL Sterile _____ Other _____	Analysis Requested Lead Lead Lead Lead Lead Lead Lead Lead Lead Lead	
EMAIL (TO SEND REPORT) mrodriguez@poughkeepsieschools.org	P.O. NUMBER/PROJECT NUMBER 220365				
PROJECT LOCATION Poughkeepsie Middle School (ams)					

SAMPLE		SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	Chlorine Residual	NUMBER OF CONTAINERS SUBMITTED											Analysis Requested
DATE	TIME							40 mL	40mL Vials HCl	40mL Vials Sulfuric	250mL Plastic	250 mL Plastic Nitric Acid	250mL Plastic Sulfuric A	250mL Plastic Sodium H	250 Amber Sulfuric	Liter Plastic	Liter Amber Glass	Liter Amber HCl	
9-18/21	9:21	Kitchen Storage BR	G		D												Lead		
9-18/21	9:23	W.F. Near Kitchen	G		D												Lead		
9-18/21	9:25	Kitchen Sink 1	G		D												Lead		
9-18/21	9:28	Kitchen Sink 3	G		D												Lead		
9-18/21	9:33	Lobby Water F	G		D												Lead		
9-18/21	9:37	Kitchen Hand Sink	G		D												Lead		
9-18/21	9:40	Main office WF	G		D												Lead		
9-18/21	9:41	Main office Sink	G		D												Lead		
9-18/21	9:45	Rm 104	G		D												Lead		
9-18/21	9:46	Rm 103	G		D												Lead		
9-18/21	9:48	WF East Wing	G		D												Lead		
9-18/21	9:53	101 Sink	G		D												Lead		

NOTES:

RELINQUISHED BY: (Print) Marcos Rodriguez	COMPANY Poughkeepsie City Schools	DATE 9/22/21	TIME 12:20	RECEIVED BY: (Print) RAK	COMPANY ETL	DATE 9/22/21	TIME 12:20
RELINQUISHED BY: (Print) Bu	COMPANY ETL	DATE 9.23.21	TIME 1648	RECEIVED BY: (Print)	COMPANY	DATE	TIME
RELINQUISHED BY: (Print)	COMPANY	DATE	TIME	RECEIVED BY: (Print)	COMPANY	DATE	TIME

RECEIVED FOR ETL BY: (Print) [Signature]	DATE 9/23/21	TIME 1648	CUSTODY INTACT? YES _____ NO _____	COOLER TEMP 1.9 C	ETL REMARKS: ICE (Y/N) pH/Preservation Check _____
--	------------------------	---------------------	---------------------------------------	-----------------------------	--



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

Lab Name **EnviroTest Laboratories** NYS DOH LAB # 10142 NJDEP LAB # NY105 CT DOPH# PH-0554
 Lab Address **316 Fullerton Avenue, Newburgh, NY 12550** Phone (845) 562-0890
 Field Office Address **312 Titusville Rd, Poughkeepsie, NY 12603** Field Office Phone (845) 229-8538

~~207076~~ 2 of 2
207104

IMPORTANT NOTE: All services performed by Envirotest Laboratories LLC are subject to our Terms & Conditions available at <http://www.envirotestlabs.com/terms> Any Rush TAT must be approved in advance by lab***

CLIENT NAME Poughkeepsie City Schools		PWS NUMBER	MATRIX TYPE		REQUIRED Containers										PAGE <u>2</u> of <u>2</u>																																												
CLIENT ADDRESS 18 So. Perry St. Poughkeepsie NY 12601		CLIENT PHONE1 (845) 451-4996		CLIENT (SITE) CONTACT Marcus Rodriguez		COMPOSITE (C) OR GRAB (G) INDICATE		AQUEOUS (WATER)		D (Drinking Water) or W (Waste Water) Indicate		SOLID OR SEMISOLID		Chlorine Residual		<table border="1"> <tr> <th>Total # of Containers</th> <th>40 mL</th> <th>40mL Vials -HCl</th> <th>40mL Vials Sulfuric</th> <th>250mL Plastic</th> <th>250 mL Plastic Nitric Acid</th> <th>250mL Plastic Sulfuric Acid</th> <th>250mL Plastic Sodium Hydroxide</th> <th>250 Amber Sulfuric</th> <th>Liter Plastic</th> <th>Liter Amber Glass</th> <th>Liter Amber HCl</th> <th>125 mL Sterile Sodium Thio</th> <th>125mL Sterile</th> <th>Other</th> </tr> <tr> <td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td> </tr> </table>										Total # of Containers	40 mL	40mL Vials -HCl	40mL Vials Sulfuric	250mL Plastic	250 mL Plastic Nitric Acid	250mL Plastic Sulfuric Acid	250mL Plastic Sodium Hydroxide	250 Amber Sulfuric	Liter Plastic	Liter Amber Glass	Liter Amber HCl	125 mL Sterile Sodium Thio	125mL Sterile	Other																TURNAROUND TIME (Biz Days)		NON-TESTING CHARGES	
Total # of Containers	40 mL	40mL Vials -HCl	40mL Vials Sulfuric	250mL Plastic	250 mL Plastic Nitric Acid	250mL Plastic Sulfuric Acid	250mL Plastic Sodium Hydroxide	250 Amber Sulfuric	Liter Plastic	Liter Amber Glass	Liter Amber HCl	125 mL Sterile Sodium Thio	125mL Sterile	Other																																													
EMAIL (TO SEND REPORT) mrodriguez@poughkeepsieschools.org		P.O. NUMBER/ PROJECT NUMBER 220305		PROJECT LOCATION Poughkeepsie Middle School (AMS)		NORMAL		P/U		SAMP		RUSH (Y/N)		GRAB		COMP																																											
DATE		TIME		SAMPLE IDENTIFICATION		RUSH (# Biz Days)		REPORTING		#OF COOLERS		OTHER		Analysis Requested																																													
9-18-21	9:54	102 Sink		G											Lead																																												
9/18/21	9:56	110 Sink		G											Lead																																												
9/18/21	9:59	Nurse Sink		G											Lead																																												
9/18/21	10:01	113 Sink		G											Lead																																												
9/18/21	10:03	120 Sink		G											Lead																																												
9/18/21	10:07	C/FM WF		G											Lead																																												
9/18/21	10:12	2nd Fl East WF		G											Lead																																												
9/18/21	10:14	2nd North WF		G											Lead																																												
9/18/21	10:19	3rd Fl East WF		G											Lead																																												
9/18/21	10:21	3rd Fl North WF		G											Lead																																												

NOTES:

RELINQUISHED BY: (Print) Marcus Rodriguez	COMPANY Poughkeepsie City Schools	DATE 9/22/21	TIME 12:20	RECEIVED BY: (Print) RAK	COMPANY ETL	DATE 9/22/21	TIME 12:20
RELINQUISHED BY: (Print) R	COMPANY ETL	DATE 9.23.21	TIME 16:48	RECEIVED BY: (Print)	COMPANY	DATE	TIME
RELINQUISHED BY: (Print)	COMPANY	DATE	TIME	RECEIVED BY: (Print)	COMPANY	DATE	TIME

RECEIVED FOR ETL BY: (Print) **Natasha Kelly** DATE **9/23/21** TIME **1648** CUSTODY INTACT? YES NO COOLER TEMP **1.9 C** ETL REMARKS: ICE (Y/N) pH/Preservation Check

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Poughkeepsie City Schools

Job Number: 420-207104-1
SDG Number: Poughkeepsie Middle School (PMS)

Login Number: 207104

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is recorded.	True	1.9C
Cooler Temp. is within method specified range.(0-4 C PW, 0-6 C NPW, or BAC <10 C	True	
If false, was sample received on ice within 6 hours of collection.	NA	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	